

2009 SERVICE STANDARD & GUIDE
REVISION LISTING

THIS IS A LISTING OF CHANGES AND IMPROVEMENTS TO THE SERVICE STANDARDS AND GUIDE THAT HAVE BEEN INCLUDED IN THE 2009 EDITION.

ELECTRIC

- 005.1 TONY LOCKSMITH'S ADDRESS CHANGED IN ORANGE COUNTY
- 006 IN TABLE 1: 226 – 400 AMPS HAS CHANGED TO "226 – 600 AMPS"
- 006.1 ADD IMPEDANCE INFORMATION TO CHART
- 013.4 EDITORIAL CHANGES
- 013.5 IN THE 3RD HEADING: SINGLE PREMISE–SINGLE RESIDENTIAL, 300 FEET IS NOW 150 FEET
- 013.6 IN THE 5TH HEADING: SINGLE PREMISE–MULTIPLE, "TO SERVE AN EXISTING BUILDING" WAS ADDED TO THE 1ST SENTENCE
- 013.7 EDITORIAL CHANGES
- 013.9 NEW NOTE ADDED
- 013.10 NEW NOTE ADDED
- 013.11 NEW NOTE ADDED
- 016 IN NOTE #4, TRUCK WEIGHT OF 4000 LBS WAS ADDED
- 016.1 DIAGRAM OF PICK UP TRUCK AND NOTES ADDED
- 016.2 NOTE #6 WAS ADDED
- 127 NOTE #6 WAS ADDED
- 128 NEW NOTE ADDED BELOW THE PICTURE OF THE POOL
- 205.3 & 205.4 CHANGES TO THE DIAGRAM SHOWING THE CUSTOMER'S SERVICE GROUND TERMINATING ON THE CUSTOMER'S SIDE OF THE PANEL, NOT THE UTILITY'S
- 301 NOTE #8 WAS ADDED
- 302 REFERENCE TO NOTE #8 WAS ADDED TO FIGURE 2
- 605 NEW NOTE ADDED TO FIGURE 1 & FIGURE 3.
THE DIAGRAM TO FIGURE 3 CHANGED FROM A RECESS METER CABINET TO A RECESS METER ONLY.
- 606 THE DIAGRAM CHANGED TO BETTER SHOW THE WORKING CLEARANCE IN FRONT OF THE METER CABINET. INFORMATION ON THE LAST SENTENCE CHANGED TO 125 – 225 AMPERE SOCKET–BASED METER INSTALLATIONS, 400 AMPERE (CL 320) RESIDENTIAL, AND 600 AMPERE CT RATED COMMERCIAL METER PANELS
- 606.1 EDITORIAL CHANGES
- 607.3 REMOVED TABLE 1
THE DIRECTIONS OF THE DIAGRAM CHANGED WITH REGARDS TO NOTE #6

TO REFLECT HE CHANGES TO 706.1

706.3 PAGE DELETED

708 ADDED DIAGRAM OF "CONDUIT PLACEMENT FOR MAXIMUM NUMBER OF CONDUITS"

GAS

1001 1,500 SCFH CHANGED TO 1,000 SCFH FOR LOAD STUDY INITIATION IN THE 4TH PARAGRAPH

1005 DELETED RM1000, RM2000 AND RM3000 METERS IN STANDARD PRESSURE TABLE.
RENAMED 1.5M TO 15C IN STANDARD PRESSURE TABLE SINCE 1.5M IS NOT BEING
INSTALLED NEW.
ADDED 630 AND 11C METERS AND ATTRIBUTES IN STANDARD PRESSURE TABLE.
UPDATED 8C RISER SIZE IN STANDARD PRESSURE TABLE.
UPDATED 2M AND 3M RISER TO HOUSELINE SPACINGS TO 48" IN STANDARD
PRESSURE TABLE.
ADDED 630 AND 16M METERS AND ATTRIBUTES TO 5 PSI TABLE.
REMOVED 15C FROM 5 PSI TABLE (USE 630 INSTEAD FOR SAME GAS FLOW).
UPDATE CAPACITIES OF 425, 8C, AND 2M METERS IN 5 PSI TABLE.
UPDATE RISER TO HOUSELINE FOR 425 METER IN 5 PSI TABLE.

1010 UPDATED TABLE FROM 250-425 METER TO 250-630 METER.
REMOVED RM1000, RM2000 AND RM3000 METERS FROM TABLE.
ADDED 2M METER AND ATTRIBUTES TO TABLE.
REPLACED 1.5M 175 METER WITH 15C METER.