

Proceeding No.: A.15-09-\_\_\_\_\_  
Exhibit No.: SDG&E-05  
Witness: Geier

**PREPARED DIRECT TESTIMONY OF**  
**DAVID L. GEIER**  
**ON BEHALF OF**  
**SAN DIEGO GAS & ELECTRIC COMPANY**

**BEFORE THE PUBLIC UTILITIES COMMISSION**  
**OF THE STATE OF CALIFORNIA**

**SEPTEMBER 25, 2015**



**TABLE OF CONTENTS**

**I. INTRODUCTION..... 1**

**II. PURPOSE OF TESTIMONY ..... 1**

**III. OVERVIEW OF SDG&E’S OPERATIONS ..... 5**

**A. SDG&E’s Service Territory..... 5**

**B. SDG&E’s Transmission and Distribution Systems ..... 6**

**C. SDG&E’s Key Operational Priorities Prior to the 2007 Wildfires ..... 9**

**IV. THE 2003 WILDFIRES ..... 15**

**V. THE 2007 WILDFIRES ..... 17**

**VI. SDG&E’S EFFORTS TO REDUCE WILDFIRE RISK SINCE THE 2007 WILDFIRES..... 19**

**VII. COMMISSION PROCEEDINGS RELATED TO THE 2007 WILDFIRES AND WILDFIRE RISK REDUCTION..... 26**

**VIII. CONCLUSION ..... 29**

**APPENDIX 1: Qualifications**

**APPENDIX 2: SDG&E 2014 Fire Prevention Plan**

1                                   **PREPARED DIRECT TESTIMONY OF DAVID L. GEIER**  
2                                   **ON BEHALF OF SAN DIEGO GAS & ELECTRIC COMPANY**

3  
4   **I.       INTRODUCTION**

5   Q.     Please state your name and business address.

6   A.     My name is David L. Geier. My business address is 8330 Century Park Court, CP33, San  
7   Diego, California.

8   Q.     What is your current position?

9   A.     I am currently employed by San Diego Gas & Electric Company (“SDG&E”) as Vice  
10   President of Electric Transmission and System Engineering.

11   Q.     What are your responsibilities in that position?

12   A.     I oversee the operations and planning of SDG&E’s transmission system and substations,  
13   including design and engineering for new and existing distribution, transmission and substation  
14   facilities. I am also responsible for the inspection and maintenance of our substation and  
15   transmission facilities. My qualifications are set forth in Appendix 1.

16   Q.     Have you previously testified before the Commission?

17   A.     Yes.

18   **II.       PURPOSE OF TESTIMONY**

19   Q.     What is the purpose of your testimony?

20   A.     I am testifying in support of SDG&E’s Application to recover its Wildfire Expense  
21   Memorandum Account (“WEMA”) Costs. Other SDG&E witnesses – including Mr. Lee  
22   Schavrien, Ms. Karen Sedgwick, Mr. Craig Gentes, and Ms. Cynthia Fang – are testifying about  
23   the reasonableness of SDG&E’s decisions related to the WEMA Costs from a regulatory and

1 policy perspective, which I understand is the focus of SDG&E's application. The purpose of my  
2 testimony – along with the testimony of Mr. Darren Weim, Mr. Greg Walters, and Mr. Don  
3 Akau – is to show that SDG&E's operations, engineering and system maintenance prior to the  
4 2007 wildfires were reasonable. My testimony is based on my personal experience in SDG&E's  
5 operations and engineering dating back more than 30 years, including my direct involvement in  
6 our response to the 2003 and 2007 wildfires, in subsequent regulatory proceedings, and in  
7 developing strategies and measures to limit the potential for future utility-related wildfires.

8 SDG&E has been and remains heavily invested in the community we serve. We provide  
9 energy service to 3.4 million people through 1.4 million electric meters and 870,000 natural gas  
10 meters in San Diego and southern Orange counties. We employ approximately 4,500 employees  
11 who live in our community. Several of the large wildfires that broke out in Southern California  
12 in late October 2007 caused widespread devastation in our community. What made the 2007  
13 wildfires catastrophic was the large size of the fires, the high number of fires burning  
14 simultaneously, and how quickly the fires spread across our service territory. These fires  
15 damaged or destroyed not only the homes and property of our customers, but also impacted  
16 many of SDG&E's employees and electric facilities. Even before the fires were extinguished,  
17 SDG&E began the massive effort of restoring power to all of its customers.

18 Today we all understand how unprecedented the 2007 wildfires were from an historical  
19 perspective. Indeed, the residents of Southern California, firefighting agencies, and this  
20 Commission are now acutely aware that wildfire risks are a substantial threat to public health and  
21 safety in a way not previously known. I think it's fair to say that no stakeholder – whether the  
22 utilities, the Commission, federal and state agencies, or the public – wants to see a recurrence of  
23 the 2007 wildfires. To this end, residents and local government agencies have been working

1 hard (many with SDG&E's assistance) to prevent and prepare for the next catastrophic fire.  
2 Indeed, this Commission has been especially active in efforts to overhaul its safety regulations  
3 with the aim of minimizing the risk of future wildfire outbreaks related to power line or  
4 communication infrastructure facilities, as is evidenced by several proceedings resulting from  
5 this 2007 wildfire event, including several decisions the Commission has issued in Order  
6 Instituting Rulemaking (R.) 08-11-005 ("Fire Safety OIR").

7 SDG&E is keenly aware of its responsibility to operate its system in a responsible and  
8 safe manner. As I describe later in my testimony, in the aftermath of the 2007 wildfires, SDG&E  
9 has taken extraordinary measures to reduce the risk that our facilities could again be linked to the  
10 start of a fire in extreme weather, including increasing our situational awareness of wind and  
11 weather conditions (as Mr. Vanderburg discusses) to enable us to better anticipate when the  
12 threat of wildfire is elevated and to take preventative actions.

13 It is tempting to argue that the involvement of SDG&E facilities in these catastrophic  
14 wildfires should preclude any recovery of the WEMA Costs. Such an argument, however,  
15 ignores critical facts and circumstances, and despite any superficial appeal, is unpersuasive from  
16 my perspective. While there were many causes and contributing factors to the ignition and  
17 spread of the numerous wildfires that erupted in Southern California in October 2007, the wind  
18 and weather conditions were a common factor in each of them, without which this catastrophic  
19 series of events would not have occurred. These conditions no doubt tested the limits of our  
20 system. Even so, reports issued by the California Department of Forestry and Fire Protection  
21 ("Cal Fire") and the Commission's Consumer Safety and Protection Division (now the Safety  
22 and Enforcement Division ("SED")) make clear that these fires were ignited and spread under  
23 extraordinary circumstances beyond SDG&E's control. According to the reports, lashing wire

1 installed and maintained by Cox Communications broke and blew into our conductor in the high  
2 winds, starting the Guejito fire. With respect to the Rice Fire, a sycamore tree limb broke in the  
3 high winds and fell onto SDG&E's conductor, starting a fire. The Witch Fire was blamed on  
4 conductor to conductor contact caused by the extreme winds.

5 This is not a situation in which SDG&E was conducting its operations without reasonable  
6 care or a high level of concern for safety. On the contrary, SDG&E took great care in the  
7 engineering, construction, and maintenance of its electric facilities prior to the 2007 wildfires.  
8 SDG&E's rigorous construction and maintenance practices met, and often exceeded, applicable  
9 regulations. Under our inspection and maintenance programs, each year we inspect thousands of  
10 poles, power lines, and other equipment, as well as trees and vegetation that may cause safety  
11 issues. These programs entail a massive effort, but despite the magnitude of the challenge,  
12 SDG&E is up to the job, and our goal is to leave no stone unturned in this effort. Importantly, as  
13 discussed by Messrs. Weim, Walters and Akau, despite exercising great care, SDG&E had no  
14 basis to know that the issues leading to the ignition of the Witch, Guejito and Rice Fires were  
15 going to occur. In sum, SDG&E acted prudently.

16 Q. How is the remainder of your testimony organized?

17 A. In Section III, I present an overview of SDG&E's service territory, its distribution and  
18 transmission systems, and its key operational priorities. In Sections IV and V, I discuss the 2003  
19 and 2007 wildfires, including SDG&E's response to those fires. In Section VI, I explain  
20 SDG&E's efforts to reduce the risk of wildfires involving utility facilities and discuss the efforts  
21 we undertook based on the lessons we have learned from these 2007 wildfires. In Section VII, I  
22 discuss Commission proceedings, in which SDG&E has participated, that have been aimed at  
23 reducing wildfire risk. In Section VIII, I conclude my testimony.


1 **III. OVERVIEW OF SDG&E'S OPERATIONS**

2 **A. SDG&E's Service Territory**

3 Q. Please describe SDG&E's service territory.

4 A. SDG&E is the third largest electric utility in California serving over 3.4 million people in  
5 San Diego, and Orange Counties, in a combined service territory of over 4,000 square miles,  
6 which is depicted in Figure 1 below.

7 **Figure 1: SDG&E's Service Territory**



8 SDG&E's service territory includes a geographic mixture of urban and rural communities,  
9 consisting of 26 cities, two counties, and 15 major military facilities. Geographically, the service  
10 territory ranges from coasts and bays to rural inland valleys, foothills, mountains, and desert  
11 terrain. The rural areas of SDG&E's service territory are characterized by smaller communities,  
12 lower density development and significant wildland areas. This area is predominantly served by  
13

1 an overhead electric distribution system, unlike the more densely developed coastal areas where  
2 the system is primarily underground.

3 Q. Do the conditions in SDG&E's service territory present a unique wildfire risk?

4 A. Yes. San Diego's geography and weather present wildfire risks. As discussed below,  
5 however, starting around the time of the 2003 wildfires, but in particular as a result of the 2007  
6 wildfires, the true nature and magnitude of these risks became clear.

7 These risks are most acute in SDG&E's rural service area, which is subject to extreme  
8 weather conditions that can foster wildfire. These conditions include summer and fall warm  
9 temperatures, strong Santa Ana winds, and low humidity, which dry out the back-country  
10 vegetation and create the risk that a small spark from any source will ignite a fire that can spread  
11 rapidly and be difficult to extinguish. We have seen these conditions worsen in recent years as a  
12 result of the effects of the drought and climate change. Approximately two-thirds of SDG&E's  
13 service territory now falls within what SDG&E has determined to be a fire threat zone in  
14 connection with mapping activities we have undertaken. These zones lie mostly within rural  
15 areas.

16 San Diego's urban areas (and particularly urban canyon areas with dry vegetation and  
17 other fuels), however, are also at risk of wildfire outbreaks due to Santa Ana wind events. In  
18 May 2014, for instance, strong and widespread wind gusts hit San Diego from the coast to the  
19 mountains. Fourteen fires occurred during this event (the three most significant of which were  
20 the Bernardo, Cocos, and Poinsettia fires), none of which were attributed to SDG&E facilities.  
21 The predominance of these fires occurred in the western half of the county, with a few fires  
22 burning near the coast. During the May 2014 event, more than 60,000 customers lost power.

23 **B. SDG&E's Transmission and Distribution Systems**

24 Q. Please provide an overview of SDG&E's transmission and distribution systems.



1 A. Today SDG&E owns, operates and maintains 1,028 distribution circuits, 241  
2 transmission circuits, and 161 electric substations. The distribution circuits operate at 12  
3 kilovolts (“kV”) and 4kV and include 223,076 poles, 10,361 miles of underground lines and  
4 6,563 miles of overhead lines. There are 14,437 transmission structures in the SDG&E  
5 transmission system, with over 1,819 miles of overhead lines and 150 miles of underground  
6 lines. Many of these systems serve rural areas of San Diego.

7 Q. What is your role with respect to these systems at SDG&E?

8 A. My organization handles a variety of functions through several key departments,  
9 including (1) Electric System Planning, (2) Electric Transmission and Distribution Engineering,  
10 (3) Major Projects, (4) Electric Grid Operations, and (5) Kearny Maintenance and Operations.  
11 There are 576 employees in these departments, including engineers, project managers, technical  
12 experts, and administrative support staff. Although I do not oversee distribution operations, I am  
13 intimately familiar with all aspects of SDG&E distribution design and operations, having held  
14 officer-level positions in that area during my career, and I have a comprehensive understanding  
15 of the unique challenges SDG&E faces in the design and operation of the electric system in San  
16 Diego County.

17 Q. Please describe the roles and responsibilities of each of the five departments in your  
18 organization.

19 A. The Electric System Planning Group is responsible for the long term planning of  
20 SDG&E’s high voltage and extra high voltage substations and transmission lines, as well as  
21 distribution lines. This group studies the SDG&E system and works in close coordination with  
22 other interconnecting utilities and with the California Independent System Operator (“CAISO”)  
23 to identify prudent, cost-effective solutions to existing or forecasted system needs.

1           The Electric Transmission and Distribution Engineering Group is responsible for  
2 engineering and design standards and project design for SDG&E's substations and transmission  
3 and distribution lines. They are responsible for the identification and implementation of all  
4 design elements for these systems, including code compliance, reliability and design for safe  
5 operations.

6           The Major Projects Group is responsible for the licensing and project management for  
7 new substations and transmission lines. This group prepares, assembles and manages project  
8 documents necessary for the regulatory process, ultimately leading to project approval. Once  
9 approved, the Major Projects Group continues to manage the projects through the construction  
10 process to project completion.

11           The Electric Grid Operations Group, in close coordination with the CAISO, is  
12 responsible for the safe and reliable operation of the SDG&E electric transmission system, which  
13 includes lines and substations operating at 69kV, 138kV, 230kV and 500kV.

14           The Kearny Maintenance and Operations Group is responsible for construction and  
15 maintenance for SDG&E substations and transmission lines. Although the majority of the new  
16 substation and transmission line construction is performed by contractors, the Kearny  
17 Maintenance and Operations Group also performs construction activities on new and existing  
18 substations and transmission lines. This group is also responsible for inspections of SDG&E  
19 transmission lines, and substations in accordance with the inspection and maintenance policies  
20 overseen by the CAISO and the Commission.

21 Q.       Please describe the roles and responsibilities of the distribution operations groups.

22 A.       The Electric Distribution Operations Control Center is responsible for the safe, efficient  
23 and reliable delivery of power to SDG&E's customers. The control center personnel have

1 overall operational control of the electric distribution system for planned and unplanned work.  
2 Emergency operations related to service restoration, Red Flag Warnings, storm response and  
3 General Order 166 requirements originate in the Distribution Control Center.

4 Electric Regional Operations (ERO) includes all electric distribution crews located in six  
5 districts and two satellite operating centers (Ramona and Mountain Empire), which covers  
6 SDG&E's entire electric distribution system and service territory. The primary job functions  
7 include: (1) inspecting and maintaining the electric distribution system in compliance with  
8 General Orders 95, 128 and 165 and the SDG&E Standards; (2) restoring service due to outages;  
9 and (3) repairing service problems and address other customer issues. ERO staffing consists of  
10 electric lineman, apprentices, line assistants, dispatchers, office support personnel, supervisors  
11 and management. ERO Compliance training consists of required training from various  
12 organizational units including Distribution Standards, Fleet, Safety, Environmental, various  
13 governmental agencies, as well as a review of standards and practices that have evolved as a  
14 pattern from operational incidents. ERO personnel complete most of their compliance training at  
15 the SDG&E Skills Training Center.

16 The Compliance and Asset Management workgroups are focused on ensuring that  
17 SDG&E maintains its compliance with internal and external regulations, policies, and procedures  
18 as they relate to operating and maintaining the electric distribution system in a safe and efficient  
19 manner. The three main subsections that comprise the Compliance and Asset Management  
20 Workgroup are the Compliance Management Group, the Program Management Group and the  
21 Aerial Marking Group.

22 **C. SDG&E's Key Operational Priorities Prior to the 2007 Wildfires**

23 Q. Based on your experience, what are the key operational and engineering priorities at  
24 SDG&E?

1 A. SDG&E's key priorities from an operational and engineering perspective have always  
2 included safety, reliability, compliance, and cost effectiveness. From a safety perspective, we  
3 strive in everything we do to operate our system in a way that avoids injury or damage to people,  
4 property and the environment. We also work hard to provide our customers with a reliable  
5 system. A reliable system is a safe system, and one which provides consistent power to those  
6 who need it most, including power to run hospitals and home medical equipment, schools,  
7 community safety devices such as street lights, and other essential services San Diego residents  
8 rely upon on a daily basis. In addition, in emergencies, reliability is extremely important since  
9 water supply, traffic signals, safe evacuations, communications, and emergency response all  
10 depend on electric power. Both before and after the 2007 wildfires, I have personally seen the  
11 consequences that can result from outages of common facilities such as traffic signals, and my  
12 colleagues and I are always mindful of the importance of keeping the electricity flowing and  
13 minimizing transmission and distribution facility outage times, even if such outages cannot be  
14 eliminated entirely, such as in extreme weather conditions.

15 As described more below and in the testimony of Messrs. Walters, Weim, and Akau, a  
16 major part of the way we work to ensure safety and reliability is by developing policies,  
17 procedures, and programs that ensure that we comply with applicable regulatory requirements  
18 and by assessing and appropriately manage the risks to our system posed by various factors,  
19 including the environment.

20 Underlying all of these considerations is our need to be cost-effective. We always have  
21 to think about the ratepayer and balance operating a safe and reliable system against the cost to  
22 our customers of doing so. Indeed, as a regulated utility, our spending decisions are carefully  
23 scrutinized by the Commission, and we must show that we are prudently balancing all of these

1 considerations when making those decisions. Sometimes, the interplay between all of these  
2 priorities forces SDG&E to make difficult choices. For example, although SDG&E has the  
3 highest proportion of underground distribution lines of any California investor-owned utility,  
4 undergrounding additional circuits – even though it may lead to safety improvements – would  
5 substantially increase rates and would pose reliability concerns. Underground systems are more  
6 expensive to install than overhead systems, difficult and less feasible to install in areas of rough  
7 terrain, they have shorter service lives, they require more time to troubleshoot problems, and  
8 repairs take longer to correct once identified. These difficulties present both financial and  
9 personal issues to effected ratepayers.

10 SDG&E does its best to balance these priorities in managing its transmission and  
11 distribution system. When priorities do not coincide, SDG&E undertakes diligent and thoughtful  
12 analysis of the risks, benefits, and costs associated with all the possible courses of action from  
13 both the customers’ and companies’ perspective.

14 Q. Prior to the 2007 wildfires, how was SDG&E ensuring that it was operating safely and  
15 reliably, and in accordance with applicable regulatory requirements?

16 A. As Messrs. Walters and Weim discuss, there are a number of General Order requirements  
17 that the Commission has established that relate to the design, construction and maintenance of  
18 overhead and underground powerlines and facilities – particularly those set forth in General  
19 Orders 95, 128 and 165. These regulations set minimum standards to ensure utilities operate  
20 safely and reliably, and (as I note below) they have been updated to be more rigorous today than  
21 they were prior to the 2007 fire events on a number of issues, including with respect to the  
22 frequency of inspections and the extent of required vegetation clearances around powerlines.  
23 SDG&E strives to meet or exceed those requirements.

1 For example, Mr. Walters discusses our General Order 165 compliance efforts dating  
2 back to the late 1990s, including our Corrective Maintenance Plan. General Order 165 governs  
3 how often and in what manner we inspect our facilities. Our compliance with those requirements  
4 is audited annually by the Commission's Safety and Enforcement Division. Similarly, Mr.  
5 Weim discusses the Transmission Line Maintenance Practice that governs our inspection and  
6 maintenance of transmission facilities both before and after 2007, which is audited annually by  
7 the CAISO. SDG&E's extensive Vegetation Management Program, which Mr. Akau discusses  
8 in detail, governs our trimming and removal of vegetation in proximity to powerlines that could  
9 pose safety and reliability concerns. That program consistently exceeded in several respects the  
10 Commission's General Order 95 requirements prior to 2007. Our consistent efforts to meet or  
11 exceed these standards ensures that we catch as many potential issues with our system as  
12 possible, and that we are providing the level of safety and reliability required by the Commission  
13 and other regulators. These programs are akin to doing regular maintenance on your car to  
14 ensure that it will not break down or get into an accident.

15 Q. Has SDG&E consistently performed well in connection with audits and reviews, or  
16 otherwise been recognized for safety or reliability?

17 A. Yes. SDG&E has consistently performed well on audits by its regulators. For example,  
18 CAISO's annual Maintenance Reviews of SDG&E's transmission system have been consistently  
19 positive, as discussed by Mr. Weim. As described in Mr. Akau's testimony, SDG&E has been  
20 recognized for the quality of our vegetation management activities by the North American  
21 Electric Reliability Council ("NERC") in its Transmission Operator Reliability Readiness Audit  
22 Report for SDG&E, dated August 14-17, 2006 and by the National Arbor Day Foundation.  
23 SDG&E has also been consistently recognized for having a very reliable electric system. In

1 particular, SDG&E has been awarded many reliability awards by PA Consulting, a leading  
2 management, systems and technology consulting firm:

- 3 • SDG&E received the ReliabilityOne™ award for “Best in the West,”<sup>1</sup> earning this  
4 regional award for nine consecutive years beginning in 2005. The selection criteria for  
5 this award comprise the following quantitative criteria applied to a grouping of more than  
6 200 investor and governmentally owned electric utilities across the United States: (1) the  
7 customer average interruption duration index (“CAIDI”); (2) the system average  
8 interruption duration index (“SAIDI”); and (3) the systems average interruption  
9 frequency index (“SAIFI”). Electric utilities and regulators across the country, including  
10 this Commission, recognize CAIDI, SAIDI and SAIFI as measures of electric system  
11 reliability.
- 12 • SDG&E received the national ReliabilityOne Award for Outstanding Reliability  
13 Performance for calendar year 2009 and again in 2014, receiving recognition for its  
14 sustained leadership, innovation and achievement in the area of electric reliability. This  
15 award recognized SDG&E’s tremendous commitment to maintaining reliability for its  
16 customers from every level of the organization based on both qualitative and quantitative  
17 criteria, gathered across Operations, Technology, and Communications.
- 18 • SDG&E was awarded the Outstanding Response to a Major Outage Event award for  
19 calendar year 2007. This award is presented to a ReliabilityOne™ regional recipient that  
20 demonstrated an ability to go above and beyond when mobilizing and activating its entire  
21 organization to respond to major events.

---

<sup>1</sup> See <http://www.paconsulting.com/introducing-pas-media-site/releases/pa-consulting-group-recognizes-north-american-utilities-for-excellence-in-reliability-and-customer-service-21-november-2013/>.

1 This recognition, and our reliability performance more generally, reflect the good work SDG&E  
2 has done in the design, construction and maintenance of facilities as well as the performance and  
3 safety culture that SDG&E has instilled among its employees.

4 Q. Does SDG&E do anything beyond complying with applicable regulations to ensure that it  
5 operates a safe and reliable system?

6 A. Yes. As I said, in many instances, our policies and practices actually exceed or are more  
7 stringent than what is required by applicable regulations. For example, prior to 2007, SDG&E  
8 exceeded applicable regulations regarding vegetation and powerline clearances, the timeframe  
9 for completing repairs of General Order 95 and 128 conditions, embedment depth of poles, and  
10 pole loading conditions.

11 We also adjust our practices as necessary to respond to new issues and challenges,  
12 whether or not a regulator requires us to do so. For example, on March 7, 2003, the Governor  
13 declared a state of emergency with respect to a significant increase in tree mortality in  
14 mountainous areas of SDG&E's service territory that resulted from prolonged drought and bark  
15 beetle infestations. These dead and dying trees posed a threat to both safety and reliability. In  
16 response, with Commission support,<sup>2</sup> SDG&E led a collaboration of stakeholders, such as Cal  
17 Fire, the U.S. Forest Service, San Diego County, the Bureau of Land Management, and others to  
18 identify the most efficient way to manage the removal of dead trees near overhead electric power  
19 lines so as a to mitigate the risk of wildfires (this effort became known as the Bark Beetle  
20 project). Thousands of dead, dying and diseased trees in close proximity to SDG&E power lines  
21 were removed by SDG&E as a result.

---

<sup>2</sup> Decision ("D.") 06-10-032.



1 Q. Prior to the 2007 wildfires, had the risk of wildfire outbreaks influenced SDG&E's  
2 operations and implicated the key priorities you previously described?

3 A. Yes. We were always mindful of the risk of fire posed by our various facilities, and the  
4 policies and procedures we implemented to ensure a safe and reliable system were directed, in  
5 part, to address that risk. Safe and reliable systems work properly. Limiting "malfunctions"  
6 limits the possibility that those malfunctions will start a fire. In addition, as I mentioned, even  
7 prior to that time we were adjusting practices and procedures to address risks like those posed by  
8 drought, and the 2003 firestorm in Southern California, which was the largest wildfire event we  
9 had experienced in our service territory prior to the 2007 wildfires.

#### 10 **IV. THE 2003 WILDFIRES**

11 Q. Mr. Geier, what do you remember about the 2003 wildfires?

12 A. I remember the 2003 firestorm well. At the time, it was the largest firestorm that had  
13 occurred in Southern California. In San Diego County alone, the 2003 wildfires burned over  
14 400,000 acres, destroyed more than 2,400 homes, and caused extensive damage to SDG&E's  
15 facilities. More than 100,000 SDG&E customers were left without power.

16 Q. What was SDG&E's immediate response to that fire?

17 A. In the immediate aftermath of the fire, the key focus of our response was to isolate  
18 powerlines damaged by the fires to make it safe for firefighters and the public. Our crews went  
19 out to the areas damaged by the fires to make sure there were no energized lines that could  
20 endanger the public. This was followed immediately with an effort to restore service to our  
21 customers and to rebuild our facilities in light of the extensive damage that was caused.

22 Approximately 3,200 power poles, 700 spans of wire, 400 transformers, and more than 100 other  
23 pieces of related equipment were damaged and needed to be replaced.

1           The restoration effort following those fires was tremendous, with SDG&E and its  
2 employees working literally around the clock to restore customer power. By November 2, 2003,  
3 only one week following the start of the fire, SDG&E had restored service to more than 102,000  
4 electric customers, and the remaining 8,000 customers (living in primarily remote areas  
5 characterized by rugged terrain) had service restored by November 20, 2003. As the  
6 Commission noted, “[t]his exceptional effort has been the subject of numerous accolades and  
7 commendations from customers as well as government officials thanking the company for a job  
8 well done.”<sup>3</sup>

9 Q.       How did the 2003 wildfires impact SDG&E from an ongoing operation standpoint?

10 A.       Post-2003 we focused our priorities on improving the integrity and reliability of our  
11 transmission and distribution systems, especially in rural areas that are most frequently the  
12 subject of extreme Santa Ana wind events. The steps we took primarily centered around  
13 improving our understanding of fire risk to our system, as well as our ability to operate in fire  
14 conditions and coordinate with fire agencies during wildfire outbreaks. We wanted to make sure  
15 we could provide power to the community during emergencies such as this, when it is needed  
16 most.

17           To that end, SDG&E created a full-time Fire Coordinator position, staffed by an  
18 experienced California firefighter. During active fires, the Fire Coordinator’s purpose was (and  
19 continues to be) to provide situational intelligence to SDG&E operations regarding the impacts  
20 to SDG&E facilities and in some cases, enhance public safety by identifying specific actions to  
21 take with energized facilities that enhance the effectiveness of firefighting crews.

---

<sup>3</sup> D.05-08-037 at 2.

1 Beyond providing critical assistance during active fires, the Fire Coordinator created a  
2 written guide to formalize practices and procedures and to provide training to SDG&E  
3 employees about wildland fire risk. This document provided guidance on fire prevention and  
4 fire safety issues. This coordinator also began maintaining a fire information database in order to  
5 track fires and causes so we could learn about patterns or issues, which we hoped would identify  
6 potential fire concerns and help us eliminate them. SDG&E also revised transmission and  
7 distribution operating practices to incorporate procedures for coordination of operations during  
8 fire conditions with other entities, such as the U.S. Forest Service, Cal Fire, the City and County  
9 of San Diego and the law enforcement offices.

10 **V. THE 2007 WILDFIRES**

11 Q. Do you also recall the 2007 wildfires?

12 A. Yes, I was in San Diego at the time of those fires and don't think anyone who lived  
13 through these fires could forget them. They are one of the most devastating events our  
14 community has experienced. At the time, I was a Vice President of Electric Transmission &  
15 Distribution for SDG&E, and the wildfires had a tremendous immediate impact on my  
16 organization. I spent the better part of two weeks in our Emergency Operations Center  
17 (SDG&E's central coordination and communications center) monitoring the fires, SDG&E  
18 system conditions, and our response to the fires, including system restoration work. I also made  
19 trips into our service territory to view first-hand the damage caused by the wildfires.

20 Q. How did the 2007 wildfires impact San Diego in late 2007?

21 A. As noted in the report prepared by state and federal agencies after the wildfires –  
22 *California Fire Siege 2007: An Overview* – which is attached to Mr. Schavrien's testimony, the  
23 2007 wildfires began on October 21, 2007 and were not fully contained until November. The

1 wildfires burned through large portions of San Diego County and SDG&E's service territory,  
2 causing widespread damage to homes and business, including the homes of SDG&E employees  
3 and SDG&E facilities. Over 80,000 of our customers lost power and hundreds of thousands  
4 evacuated their homes. My family was among those who had to evacuate their homes, as were  
5 the families of many of my colleagues.

6 Q. What steps did SDG&E take in the immediate aftermath of the 2007 wildfires?

7 A. Our response to the 2007 fires was similar to our response in 2003, only larger. We  
8 began mobilizing personnel as soon as the fires broke out, with personnel from Electric  
9 Distribution Operations and the Emergency Operations Center monitoring the fires and system  
10 conditions. As noted, the 2007 wildfires caused widespread power outages, and SDG&E put in  
11 an enormous effort to make the damaged areas safe and to restore service to customers. At the  
12 peak of the wildfires, thousands of SDG&E employees were committed to this effort, together  
13 with an additional 203 mutual assistance personnel, plus 78 contract electric crews and 129  
14 digging crews. While service to all SDG&E customers was restored by November 12, 2007,  
15 work on the system continued at an intense level even after that date. Following restoration,  
16 additional inspections were required, and additional pole replacements and system repairs  
17 occurred. During the service restoration process for the 2007 wildfires, a total of 1,605  
18 distribution and 211 transmission poles were replaced. As of December 31, 2008, a total pole  
19 count for replacement associated with the fires had reached over 1,900 distribution poles and  
20 more than 270 transmission poles. SDG&E also replaced approximately 341 spans of  
21 distribution wire, 338 transformers, and numerous associated pieces of equipment. SDG&E's  
22 response to the 2007 wildfires is further discussed in our application to recover costs record in

1 the catastrophic event memorandum account, which resulted in a Commission-approved  
2 settlement.<sup>4</sup>

3 Q. Prior to the 2007 wildfires, did SDG&E have any reason to believe that its facilities  
4 would be involved in the ignition of the Witch, Guejito and Rice Fires?

5 A. No. It is always tempting to look at situation in hindsight and to speculate on what you  
6 could have done as an organization if you could predict the future. However, based on what we  
7 knew in October 2007, we were doing what we could to operate safely and reliably at a  
8 reasonable cost and did not know our facilities would be implicated in one fire, let alone three  
9 fires.

10 **VI. SDG&E'S EFFORTS TO REDUCE WILDFIRE RISK SINCE THE 2007**  
11 **WILDFIRES**

12 Q. Have the key operational priorities you discussed above changed since the large 2007  
13 wildfires?

14 A. No, they have not, but the balance of those priorities has changed. As I noted previously,  
15 we often find ourselves adjusting our practices or rebalancing priorities based on new issues and  
16 challenges, or as new technology becomes available, and our response to the 2007 wildfires is  
17 certainly an example of that. After the 2007 fires, SDG&E incorporated lessons learned into our  
18 practices and procedures in an attempt to further reduce the risk that SDG&E facilities could  
19 cause fires in extreme conditions. We continue to strive to improve how we conduct our  
20 operations in accordance with these priorities.

21 Q. What steps has SDG&E taken since the 2007 wildfires to reduce the risk that utility  
22 facilities will be involved in future wildfires?

---

<sup>4</sup> D.10-10-004.

1 A. Following the 2007 wildfires, SDG&E's management directed the company (including  
2 me) to undertake a review of operations and implement any changes necessary to minimize the  
3 risk of utility-related wildfires. As a result, we have taken a number of measures to understand  
4 the increased potential for wildfires in our service territory, to minimize that risk, and to quickly  
5 respond to wildfires that do occur. We began taking such steps immediately after the 2007  
6 wildfires.

7 Q. Were you personally involved in those efforts?

8 A. Yes, I was involved at the outset, and I continue to be involved today.

9 Q. Please describe the specific actions SDG&E has taken.

10 A. SDG&E's actions are described in detail in SDG&E's 2014 *Fire Prevention Plan*, which  
11 is attached as Appendix 2 and is the most recent, comprehensive description of our ongoing fire  
12 prevention activities. These efforts began in 2008 and have evolved through the present. As  
13 reflected in the *Fire Prevention Plan*, certain key actions include the following:

- 14 • Extensive fire mapping to determine areas of highest fire risk
- 15 • System hardening (including wood to steel pole)
- 16 • Quality Assurance/Quality Control program on both Transmission and
- 17 Distribution in the Highest Risk Fire Area
- 18 • Increased Vegetation Management
- 19 • Enhanced coordination with Communications Infrastructure Providers
- 20 • Added 170 new weather stations
- 21 • Hired three full time meteorologists
- 22 • Developed weather predictive tools
- 23 • Developed crew mobilization strategy and initiated patrols during severe weather
- 24 events
- 25 • Added fire coordinators to our staff
- 26 • Added the industrial fire brigade
- 27 • Added fire-fighting support
- 28 • Added mobile communication trailers
- 29 • Developed various customer outreach programs and the reverse 211 system in the
- 30 event of emergencies

- Enhanced coordination with firefighting and emergency response agencies

I describe these efforts in greater detail below:

**Fire Prevention**

Mapping: SDG&E has done extensive mapping of its service territory to identify those areas at greatest risk of uncontrolled wildfires, delineating Fire Threat Zones and Highest Risk Fire Areas, in order to better understand how to improve its facilities in light of the wildfire risk.

System Hardening: Using those maps, SDG&E has evaluated and undertaken investments (starting in 2007) to fire-harden its transmission and distribution systems. Beginning in 2010, SDG&E assembled a multi-disciplinary technical team of subject matter experts – the Reliability Improvements in Rural Areas Team – which oversaw fire hardening activities but also more broadly sought to understand fire risk, mitigation options, and priorities for related capital and operating projects. In 2014, the Fire Risk Mitigation Team (FiRM) was developed, and it is involved in such fire-hardening activities as replacing aged line elements and safeguarding facilities from known local conditions. Key system hardening actions we have undertaken since 2007 include: (1) implementing more stringent design and construction standards; (2) large-scale replacement of wood poles with steel poles; (3) undergrounding power lines in certain areas; (4) deploying new pulse reclosers; and (5) installing extensive new fire detection and alert systems.

Quality Assurance and Quality Control: SDG&E has enhanced and intensified its inspection and maintenance programs (which are described by Messrs. Weim and Walters) to focus on minimizing the probability that its facilities will be involved in the ignition of fires.

Vegetation Management and Clearance Program: SDG&E has enhanced its inspections in Highest Risk Fire Areas, and to the extent unsafe conditions are detected, an order to complete

1 the necessary work is issued prior to the start of the annual fire season. SDG&E has also sought  
2 to replace certain equipment attached to poles to further reduce fire ignition sources.

3 Communications Infrastructure Providers: SDG&E has developed and implemented a  
4 program to enhance its coordination with Communications Infrastructure Providers who seek to  
5 attach their facilities to SDG&E poles, which is designed to assure that all overhead facilities are  
6 in good repair and compliance with applicable regulations.

7 Workforce Training: SDG&E has adopted an extensive set of work rules and training  
8 programs designed to minimize the likelihood that its personnel or facilities will be involved in  
9 the ignition of fires. In addition, SDG&E has adopted and implemented the principles of an  
10 incident command system to provide a structure for disciplined communications and decisions in  
11 fire threat or fire emergency situations.

### 12 **Fire Awareness and Readiness**

13 Situational Awareness: Since 2009, SDG&E has developed an unprecedented utility  
14 practice of using a high-resolution weather databases (as discussed by Mr. Vanderburg) to  
15 identify areas posing high threats of wildfires. The SDG&E weather databases are continually  
16 updated using information from our 170 weather stations, which SDG&E has been installed  
17 since the 2007 wildfires. Our meteorology department prepares “Operating Condition”  
18 assessments each day, which track the potential for wildfire outbreaks. These Operating  
19 Condition forecasts reflect a combination of heat, humidity, wind, and other conditions, which  
20 tracks the potential for fires occurring in any region in the SDG&E service territory. This  
21 information is shared broadly within the company and is used by relevant personnel to make  
22 operational decisions on our system to reduce the risk of fire as appropriate.



1           Our three full-time degreed and experienced meteorologists on staff have also  
2 collaborated in the development of the Santa Ana Wildfire Threat Index (as discussed by Mr.  
3 Vanderburg), which converts environmental, statistical and scientific data into an easy to  
4 understand forecast of the short-term fire threat in specific locations. This information is again  
5 used internally to guide operational decision-making and is shared with local agencies, such as  
6 Cal Fire, that have fire suppression responsibilities and the public more broadly.<sup>5</sup>

7           Emergency Operations Center: SDG&E has developed procedures and protocols for  
8 communicating certain weather warning information to company personnel and for activating  
9 and staffing its Emergency Operations Center – a secure and dedicated facility that serves as a  
10 command center for SDG&E operations in high-threat conditions that has been in place since  
11 1998. During Red Flag warning conditions, SDG&E activates the Emergency Operations  
12 Center.

13           Crew Mobilization and Deployment Strategy: SDG&E developed a strategy for the  
14 deployment of appropriate resources – such as Electric Troubleshooters, construction crews, and  
15 personnel from the Utility Wildfire Prevention Team (a team of wildfire response trained  
16 personnel) – to address fire threats or events. These personnel may be assigned to observe an  
17 area where extreme weather is forecasted so that SDG&E may deploy appropriate resources. For  
18 example, SDG&E stages crews during Red Flag Warning events to respond to weather-related  
19 hazards and outages.

20           Field Patrols: In certain Operating Conditions (primarily where there is an increased fire  
21 potential), SDG&E will initiate patrols of its facilities, particularly to inspect circuits where

---

<sup>5</sup> See, e.g., <http://sdgweather.com/>.

1 unplanned outages occur. Unplanned outages can occur for many different reasons, including  
2 but not limited to tree contact, lightning strikes, mylar balloons contact.

### 3 **Fire Response, Coordination and Firefighting**

4 Fire Coordination Personnel: SDG&E employs a full time staff of experienced Fire  
5 Coordinators and contracts for additional resources as necessary. The Fire Coordinators are  
6 experts in fire behavior, fire prevention and firefighting techniques, and they are SDG&E's  
7 liaisons with fire agencies. They also advise SDG&E personnel in fire threats and prevention,  
8 and they advise fire agency personnel in electric and gas safety training matters. During a fire,  
9 the fire coordinators work closely with SDG&E's Emergency Operations Center.

10 Firefighting Assets and Resources: SDG&E has bolstered its resources for firefighting in  
11 several major ways. First, as previously noted, SDG&E now has a Utility Wildfire Prevention  
12 Team consisting of wildland fire-suppression trained personnel and trucks. These resources are  
13 dispatched with work crews on days when fire threat is elevated. Second, SDG&E's Aviation  
14 Services Department coordinates the provision of aerial resources in firefighting efforts in  
15 collaboration with local agencies. Starting in October 2009, SDG&E made an Erickson Aircrane  
16 available to local firefighting agencies during fire season. Third, SDG&E contracted a full-time  
17 Industrial Fire Brigade, which is on duty around the clock. Fourth, SDG&E maintains a  
18 collection of other important assets, such as portable emergency generators, mobile field  
19 command trailers, satellite phone booths, and other emergency equipment.

### 20 **Fire Preparedness and Community Outreach**

21 Community Outreach and Public Awareness: SDG&E has a multi-level approach to  
22 community education and outreach. First, as part of our Fire Safety Stakeholder Council, we  
23 invite community leaders and the public to participate in a collaborative fire safety process,

1 which has led to many potential solutions aimed at preventing wildfire outbreaks. Second,  
2 SDG&E coordinates with fire agencies in training events and other response drills, and to  
3 increase public awareness and emergency preparedness more broadly. SDG&E chairs the  
4 California Utilities Emergency Association, a collaboration involving utilities, emergency  
5 services agencies and the California Emergency Management Agency. Third, SDG&E partners  
6 with non-profit organizations that promote emergency preparedness and safety (*e.g.*, the  
7 American Red Cross). Lastly, SDG&E communicates with the public when fire-threat  
8 conditions are elevated or extreme.

9 Fire Preparedness Website: SDG&E maintains a public website that focuses on a range  
10 of safety issues (*e.g.*, gas safety, electric safety, fire safety, tree safety, emergency preparedness,  
11 generator safety) and outages information.

12 Fire Mitigation Funds: As part of the Sunrise Power Link Project, SDG&E funds two  
13 fire mitigation funds – the “Powerline Firefighting Mitigation Fund” and the “Defensible Space  
14 and Structure Hardening Grant Fund.” These funds provide money to fire agencies and eligible  
15 property owners, respectively.

16 Q. Do you believe that SDG&E lacks the incentive to reduce the risk of future wildfires and  
17 will stop these activities if it is permitted to recover the WEMA Costs in this proceeding?

18 A. No. Our commitment to reducing wildfire risk is a central tenet of our business, and  
19 regardless of the outcome of this case, we will continue that commitment. All of the steps that I  
20 just described demonstrate that we already devote substantial resources to reducing wildfire risk,  
21 both on our own initiative, and in conjunction with rulemakings and other Commission  
22 proceedings. Moreover, SDG&E recognizes that it will be required to make prudent decisions in  
23 the future regardless of the outcome of this case.

1 **VII. COMMISSION PROCEEDINGS RELATED TO THE 2007 WILDFIRES AND**  
2 **WILDFIRE RISK REDUCTION**

3 Q. Since the 2007 wildfires, have there been Commission proceedings related to reducing  
4 the risk of future wildfires involving utility facilities?

5 A. Yes, there have been several Commission proceedings since the 2007 wildfires which  
6 have made substantial revisions to safety rules and regulations that relate to fire risk and safety  
7 risk. I believe that the depth and extent of these proceedings shows that the 2007 wildfires  
8 spurred the Commission to reevaluate its regulations and focus on fire prevention in a way it had  
9 not done prior to the fires, and that updates to state-wide regulations would be needed to  
10 adequately deal with the newly understood catastrophic wildfire risk. SDG&E has actively  
11 participated in each of these proceedings. Based on its own efforts to better understand and  
12 prevent the risk of wildfires related to utility facilities, many of which I described above,  
13 SDG&E has sought to assist the Commission and other stakeholders in developing the best  
14 possible rules and regulations.

15 Q. How did these proceedings start?

16 A. In November 2007, in the immediate aftermath of the 2007 wildfires, SDG&E filed a  
17 petition for a Commission Order Instituting Rulemaking. In that petition, SDG&E requested that  
18 the Commission examine whether additional regulations or rules should be adopted with respect  
19 to disaster preparedness and management, particularly in the context of General Order 95.  
20 SDG&E also recommended that, in evaluating potential changes to General Order 95 and related  
21 issues, the Commission consider how best to coordinate the efforts of the many agencies, local  
22 jurisdictions, municipalities, and other stakeholders involved in disaster preparedness, response,  
23 and recovery. While SDG&E did not propose specific regulations, it flagged several key issues  
24 for the Commission's consideration, including whether rural power lines should be operated

1 differently in emergency situations and whether new design criteria (*e.g.*, for steel poles,  
2 underground power lines) should be adopted. The Commission denied this petition as  
3 premature.<sup>6</sup>

4 Q. What happened next?

5 A. In November 2008, the Commission issued the Fire Safety OIR (R.08-11-005), indicating  
6 that its purpose was to consider additional safeguards for utility and communications  
7 infrastructure providers in light of the 2007 wildfires. As a result of these proceedings, the  
8 Commission made numerous changes to its General Order requirements, particularly with  
9 respect to Extreme and Very High Fire Threat Zones in Southern California. Among the major  
10 changes, the Commission: (1) developed new requirements for Communications Infrastructure  
11 Providers with respect to inspections, maintenance and repairs; (2) changed vegetation clearance  
12 and trimming requirements; (3) addressed pole overloading; (4) increased the frequency of  
13 patrol inspections; and (5) has been refining fire mapping.

14 The Fire Safety OIR continued through early 2015 and will continue to evolve, as  
15 reflected in the recently-issued Order Instituting Rulemaking (R.)15-05-006 that is intended to  
16 develop and adopt fire maps and further refine fire safety regulations. SDG&E has been heavily  
17 involved in all phases of these proceedings – filing extensive comments and briefs and  
18 participating in numerous stakeholder workshops. Other SDG&E witnesses have participated in  
19 these proceedings. In several instances, the Commission has specifically adopted SDG&E’s  
20 recommendations and proposals on disputed issues, including with respect to General Order 95,  
21 Rule 18A<sup>7</sup> and General Order 95, Rule 91.5.<sup>8</sup> This extensive process demonstrates that the 2007

---

<sup>6</sup> D.08-05-030.

<sup>7</sup> D.12-01-032 at 43.

1 wildfires, and SDG&E’s proactive response in the wake of those fires, has significantly  
2 influenced the Commission’s understanding as to appropriate fire-safety measures.

3 Q. Has the Commission previously investigated Witch, Guejito and Rice fires?

4 A. Yes. In November 2008, the Commission initiated two investigations, one with respect to  
5 SDG&E and the Witch and Rice Fires (I.08-11-006), and the other with respect to SDG&E and  
6 Cox and the Guejito Fire (I.08-11-007) (“OII’s”). The Commission’s purpose was to determine  
7 whether SDG&E and Cox “violated any provision of the Public Utilities Code, general orders,  
8 other rules, or requirements” in connection with the facilities implicated in the fires.<sup>9</sup> In the  
9 OIIs, CPSD alleged violations of General Order 95 and failure by SDG&E to cooperate with  
10 CPSD’s investigation. SDG&E denied those allegations.

11 Q. Were you involved in these proceedings?

12 A. Yes. On behalf of SDG&E, I presented direct testimony in both of the investigations.

13 Q. How were those investigations resolved with respect to SDG&E?

14 A. The investigations were ultimately settled.<sup>10</sup> The positions of the parties are succinctly  
15 summarized in the “Joint Motion of the [CPSD] and [SDG&E] (U 902 E) for Approval of  
16 Settlement Agreement,” dated October 30, 2009. Among other provisions, SDG&E agreed to  
17 make settlement payments of \$14.35 million to the State, and up to an additional \$400,000 to  
18 implement a computer work module for CPSD’s future audits and investigations. There was no  
19 finding or admission of liability with respect to the fires.

---

<sup>8</sup> *Id.* at 126-27

<sup>9</sup> *Order Instituting Investigation, Notice of Hearing, and Order to Show Cause*, November 12, 2008 (I.08-11-006) at 1; *Order Instituting Investigation, Notice of Hearing, and Order to Show Cause*, November 12, 2008 (I.08-11-007) at 1.

<sup>10</sup> There was also a settlement agreement between Cox and CPSD regarding the Guejito Fire.

1 Q. Please describe the major features of the settlement agreement pertaining to Cox.

2 A. Cox also settled, on similar terms. In short, Cox agreed to (1) develop and implement  
3 enhanced inspection policies and practices; (2) develop and implement enhanced maintenance  
4 policies and practices; and (3) to make settlement payment of \$2 million to the State. Again, no  
5 findings or admissions of liability were made.

6 Q. Did the Commission approve these settlement agreements?

7 A. Yes. On April 26, 2010, the Commission issued D.10-04-047. In that decision, the  
8 Commission approved the settlement agreements and closed the investigations, finding that the  
9 agreements were reasonable, consistent with law, and in the public interest.

## 10 **VIII. CONCLUSION**

11 Q. In sum, how would you describe SDG&E's position with respect to the 2007 wildfires  
12 and the risk of future wildfires related to utility facilities?

13 A. I believe that SDG&E was operating prudently prior to the 2007 wildfires. We had  
14 substantial processes and procedures in place to ensure that we operated safely and reliably (and  
15 in accordance with our other operational priorities), beginning with the design and construction  
16 of our facilities and including our maintenance and inspection practices. But there is no question  
17 that we learned major lessons from the 2007 wildfires, and our entire company is completely  
18 dedicated to avoiding future catastrophic wildfires involving utility facilities. We fully recognize  
19 that such wildfires are the greatest risk we face as a community and as a business, and we will  
20 continue to enhance and refine the steps we take to eliminate that risk.

21 Q. Does this conclude your direct testimony?

22 A. Yes it does.

# **APPENDIX 1**



## **STATEMENT OF QUALIFICATIONS OF DAVID L. GEIER**

My name is David L. Geier. I am currently employed by San Diego Gas & Electric Company (“SDG&E”) as Vice President of Electric Transmission and System Engineering. I oversee the operations and planning of SDG&E’s transmission system and substations, including design and engineering for new and existing distribution, transmission and substation facilities. I am also responsible for the inspection and maintenance of our substation and transmission facilities.

Prior to assuming my current position, I served as Vice President of Electric Operations, and before that, I served as Vice President – Electric Transmission and Distribution. Other roles I have held include Director of Electric Grid Services, Director of Electric Distribution Services, Manager of Direct Access Implementation, and Manager and Supervisor at several of SDG&E’s operations and maintenance facilities. I have extensive experience in Distribution Operations, and Distribution Construction and Maintenance, all of which were part of my responsibilities at some point during my 30-plus years at SDG&E. I joined SDG&E in 1980 after working for Wisconsin Electric Power Company in Milwaukee.

In addition to my work at SDG&E, I currently serve on the Board of Directors and am Vice Chairman of the San Diego and Imperial County Red Cross. I am on the Dean’s Advisory Board at San Diego State University. I am also on the Executive Board of the University of California San Diego, Jacobs School of Engineering Corporate Affiliates Program. I am a member of the Institute of Electrical & Electronic Engineers and was formerly a Chairman of that organization’s power engineering society of San Diego.

I hold a Bachelor of Science degree in Electrical Engineering from the University of Illinois and a Master’s of Science in Electrical Engineering from San Diego State University. I

am a registered Professional Electrical Engineer in California. I have previously testified before the California Public Utilities Commission.

## **APPENDIX 2**

**SAN DIEGO GAS & ELECTRIC COMPANY**  
**FIRE PREVENTION PLAN**



**OCTOBER 31, 2014**

## TABLE OF CONTENTS

I. Executive Summary .....	4
II. Minimizing Sources of Ignition .....	8
A. Mapping the High-Risk Fire Areas in the SDG&E Service Territory .....	8
1. Mapping the Fire Threat Zone .....	8
2. Mapping the Highest Risk Fire Area .....	9
B. Fire-Hardening the SDG&E System .....	10
1. Design and Construction Standards .....	12
2. Wood-to-Steel Program .....	12
3. Undergrounding Line Segments and Facilities .....	13
4. Automated Reclosers .....	14
5. Fire Detection and Fire Alerts .....	14
6. Testing and Deploying Emerging Technologies .....	15
7. Facility Inspection and Repair Program .....	16
8. Oversight of Activities in the Rural Areas .....	17
9. Fire Risk Mitigation (FiRM) Program .....	19
III. Operational Practices for Reducing the Risk of Ignition .....	19
A. System Management: Quality Assurance and Quality Control .....	19
B. Enhanced Vegetation Management and Clearance Program .....	21
C. Coordination with Communications Infrastructure Providers .....	22
D. Workforce Training and Field Practices .....	22
IV. Mitigating the Threat of Fire: Awareness and Readiness .....	23
A. Situational Awareness .....	23
B. The Fire Potential Index .....	26
C. The SDG&E Emergency Operations Center .....	26
D. Crew Mobilization and Deployment Strategy .....	30
E. Field Patrols .....	30
V. Fire Suppression and Recovery .....	30
A. Fire Coordination Personnel .....	31
B. Firefighting Assets and Resources .....	31
1. Utility Wildfire Prevention Team .....	31

2. Aviation Services Department .....	32
3. The Industrial Fire Brigade.....	32
4. Miscellaneous Assets .....	33
C. Recovery Activities .....	33
D. Fire Incident Data Collection Plan.....	34
VI. Community Outreach and Public Awareness .....	35
A. Fire Safety Stakeholder Council.....	35
B. Partnering with Firefighting Agencies .....	35
C. Community Partnerships .....	36
D. Fire Preparedness Website.....	38
E. Fire Mitigation Funds .....	38
Appendix A - 2014 Map of SDG&E FTZ, HRFA, and Meteorologist Network.....	40

## I. Executive Summary

San Diego Gas & Electric Company ("SDG&E") provides this Fire Prevention Plan in compliance with Ordering Paragraphs 2, 4 and 5 of Commission Decision 12-01-032 (the "*Fire Safety Order*"), and Standard 1.E of General Order (GO)166. Those Ordering Paragraphs in Decision 12-01-032 provided the following directions:

2. Each investor-owned electric utility in Southern California shall (i) prepare a fire-prevention plan, and (ii) file and serve a copy of its fire-prevention plan by December 31, 2012, via a Tier 1 compliance advice letter.
  
4. The fire-prevention plans required by today's decision shall address situations where all three of the following conditions occur simultaneously: (i) three-second wind gusts exceed the structural or mechanical design standard for the affected overhead power-line facilities, (ii) these three-second gusts occur during a period of high fire danger, and (iii) the affected facilities are located in a high fire-threat area.
  
5. The fire-prevention plans required by today's decision shall specify (i) how the investor-owned electric utility will identify the occurrence of three-second wind gusts that exceed the structural or mechanical design standards for overhead power-line facilities; and (ii) the countermeasures the utility will implement to mitigate the threat of power-line fire ignitions.

A. Standard 1.E was added to GO 166 in January 2012 and was modified by Decision 14-05-020 (May 15, 2014). Standard 1.E requires SDG&E to prepare and submit plans to prevent power-line fires during extreme fire-weather events. As ordered by D.12-01-032, SDG&E submitted its first Fire Prevention Plan (FPP) by Advice Letter 2429-E on 12/31/2012. Resolution E-4576 (issued May 23, 2013) required SDG&E to make minor modifications to its FPP; these modifications were incorporated by SDG&E's supplemental Advice Letter filing 2429-E-A. The supplemental AL 2429-E-A was approved by a disposition letter from the Director of the CPUC's Energy Division on June 18, 2013, with an effective date of May 23, 2013. Consistent with General Order 166, D.12-01-032, and D.14-05-020, SDG&E's updated 2104 FPP is attached to this report as Appendix 1.



The SDG&E Fire Prevention Plan provides a comprehensive inventory of the organizational and operational activities SDG&E undertakes in order to address the risk of fire in the SDG&E service territory. The catastrophic wildfires which devastated San Diego County in 2007, unprecedented in their sheer magnitude, resulted in an enduring culture change reflected throughout SDG&E's utility operations, system and facilities, organization, and corporate goals and objectives. As evidenced in this Fire Prevention Plan, SDG&E has a company-wide, single-minded focus on addressing and minimizing wildfire-related risks to public health, safety and welfare. SDG&E's commitment to fire safety, prevention, mitigation, control, and recovery is a central tenet of our corporate culture. SDG&E takes a leadership role in addressing fire threats in the communities we serve and shares our personnel, resources, information, communications facilities, and/or fire-defense assets so as to enhance the capabilities of our local communities to defend against any repeats of catastrophic wildfire events experienced in southern California.

The SDG&E Fire Prevention Plan reflects a broad range of activities performed throughout the SDG&E organization. The Fire Prevention Plan is subject to the direct supervision of senior management, and its effectiveness is a performance measure for many SDG&E employees, some of whom are directly or indirectly responsible for contributing to and/or performing the activities described in the Fire Prevention Plan. The SDG&E Fire Prevention Plan begins with system design, construction, operation, maintenance, inspection, and repair activities aimed at significantly reducing the potential for SDG&E facilities to become the source of ignition for a fire. Nevertheless, the ubiquity of our facilities and the range of operating conditions faced in the SDG&E service territory present some risk that our facilities, no matter how diligent or conservative our practices, might become the original or contributing source of ignition for a fire. To address this risk, SDG&E has implemented extensive operational programs designed to monitor the system closely whenever and wherever the threat of fire is elevated so that, in the event of an ignition, the threats to public safety from fire are quickly abated or mitigated as fully and quickly as possible. These programs include gathering and analyzing the data from SDG&E's 149 weather stations, the third-largest private meteorological network in the country, to determine where and when the threat of a wildland fire will present itself, which in turn facilitates the immediate organization and implementation of the SDG&E response appropriate to the threat.



SDG&E monitors all wildland fires in its service territory. These are fires that burn vegetation and are capable of propagation and may also threaten SDG&E facilities or may involve an SDG&E asset.

SDG&E's Fire Prevention Plan also includes firefighting and fire-recovery activities. In the event fire conditions threaten public safety or SDG&E facilities or may involve an SDG&E asset, SDG&E will mobilize an appropriate range of resources including trained firefighting assets, communications capabilities, data and information collection, and command facilities, to address fire threats and assure the earliest possible recovery from a fire event in the affected communities.

Finally, the SDG&E Fire Prevention Plan is a "living document". In coordination with our many stakeholders, community leaders and the public, SDG&E shares and vets the Fire Prevention Plan so as to assure its continuous improvement and maximum effectiveness. Community outreach and communications are also important aspects of the fire prevention, mitigation and recovery activities included in the Fire Prevention Plan. As SDG&E has shared and vetted the Fire Prevention Plan with stakeholders and the public, the process has created a natural audience for disseminating information before, during and after conditions related to fires and the threat of fire. This audience is an important part of the communications chain used to broadcast threat and event information.

The activities described in SDG&E's Fire Prevention Plan have earned SDG&E various accolades for planning and performance. Beginning in 2005, SDG&E has been ranked "Best in the West" in reliability by PA Consulting Group, earning their regional ReliabilityOne award for eight consecutive years. SDG&E also received PA Consulting Group's National Award for Outstanding Reliability Performance in 2010.<sup>1</sup> In 2008, SDG&E received PA Consulting Group's award for Outstanding Response to a Major Outage Event for our response to the 2007 wildfires. SDG&E has also been designated as a Tree Line USA utility by the National Arbor Day Foundation in recognition of our "best practices in utility arboriculture".<sup>2</sup> More recently, SDG&E received the Fire Safe Council Partner of the Year award for

---

<sup>1</sup> Information regarding PA Consulting Group's international consulting practice and best practices awards program for the electric utility industry can be found at the firm's public website and the following address: <http://www.paconsulting.com/industries/energy/merchant-utility/improving-performance-of-utility-through-benchmarking/polaris/r1-and-s1-awards/>.

<sup>2</sup> Information regarding the National Arbor Day Foundation and The Tree Line USA program, operated in conjunction with the National Association of State Foresters, can be found at the Foundation's public website and the following address: <http://www.arborday.org/programs/treelineusa/summary.cfm>.

demonstrated leadership with community defensible space funding.<sup>3</sup> These awards validate our efforts to assure our Fire Prevention Plan is best in class and grounded in the purposes we share with the communities we serve.

Although SDG&E measures and records data such as the "three second gusts" this specific information is not used as the single data point upon which to develop and put in place the many programs that SDG&E employs in the overall prevention of fire within its service territory as described in this plan.

The goals and activities included in the SDG&E Fire Prevention Plan focus on a comprehensive and integrated assessment of the risks of fire posed by SDG&E's overhead electric system. This assessment involves an assessment of SDG&E's equipment and facilities, weather conditions, the density and condition of potential fuels such as vegetation, and the potential threat to public safety, health and welfare using value at-risk measures, all as depicted in the graphic below.



SDG&E's commitment to fire safety, prevention, mitigation, control, and recovery is a central tenet of our corporate culture. With this overarching view of fire risk assessment in mind, SDG&E presents the activities comprising its Fire Prevention Plan.

---

<sup>3</sup> Information regarding the Fire Safe Council (California Chapter), its extensive membership and Partner of the Year Award can be found at the Council's public website and the following address: <http://www.firesafecouncil.org/about/index.cfm>.

## **II. Minimizing Sources of Ignition**

The SDG&E Fire Prevention Plan is founded upon the goal of minimizing the probability that the various components of its sixty nine kilovolt transmission and twelve kilovolt distribution system might become the original or contributing source of ignition for a fire. SDG&E evaluated the prudent, cost-effective changes and improvements to its physical assets that could and should be made in order to meet this objective and implemented a preventative operations, construction and maintenance plan consistent with these evaluations.

### **A. Mapping the High-Risk Fire Areas in the SDG&E Service Territory**

SDG&E has performed and completed extensive mapping of its service territory to identify those areas at greatest risk to the occurrence of uncontrolled fires. Through these efforts, SDG&E identified two sets of geographic areas based on the potential risk of fire in the area and the threat to the public safety posed by fire. These two areas are known as the "Fire Threat Zone" (FTZ) and the "Highest Risk Fire Area"(HRFA). Generally, the FTZ includes the geographic areas most prone to wildfire due to local environmental conditions and features, and the HRFA includes areas within the FTZ where the risk of fire is the greatest.

#### **1. Mapping the FTZ**

As part of its response to Commission Rulemaking 08-11-005, SDG&E mapped its service territory to identify those areas where, due to local environmental conditions and features, the potential for wildfire was relatively high. This FTZ would be used to identify the areas where enhancements to rules, regulations and standards could reduce the potential for electric systems and facilities to ignite fires and thereby increase public safety and system reliability.

The FTZ mapping effort followed several key, objective principles. First, the FTZ was defined using parameters that would result in relatively constant boundaries not subject to continuous change and revision. This resulted in the use of criteria that tended to be conservative, *i.e.*, more inclusive than exclusive, so that the FTZ would describe the complete domain where the potential for wildfire was relatively high. Additionally, the FTZ map would need to be easily understood by key personnel and users, whether utility or other public officials, who might rely upon it in performing their job responsibilities.

In performing the mapping task, SDG&E began with the vegetation data developed and maintained by the California Department of Forestry and Fire Protection ("CAL FIRE"). These data were available on the CAL FIRE Fire and



Resource Assessment Program ("FRAP") website. Using this data, SDG&E mapped the FTZ in its service territory. This zone encompasses most of the vegetated rural areas in the Counties of San Diego and Orange. Compared to the HRFA described below, the FTZ includes areas where the density of vegetation is relatively low. The FRAP maps describe the fire risks in certain areas as "low", "moderate", "high", "very high", and "extreme". Generally, the FTZ include all of the areas described in the FRAP maps as "extreme" and "very high" risk, and some portion of the areas described as "high" risk. In shaping the FTZ, SDG&E also applied its knowledge of its service area and internally developed high-resolution weather data and histories.

Because SDG&E personnel will use the FTZ map for various purposes, it was important to make the FTZ map easy to use and understand. One particular adjustment made by SDG&E to the raw data upon which the map was based was to create a contiguous FTZ, rather than create a multitude of "pockets" of high risk. The original data created a mosaic of areas of varying degrees of risk – such a map would have been difficult to interpret and use. As an example, based purely on the raw weather and vegetation data, there would have been areas where the risk of fire would have been designated as "low", "very high", and "low" again along a one-mile stretch of road. Rather than include and parse anomalies, SDG&E adjusted the shape of the FTZ to normalize the design, construction, operations, maintenance, and inspection activities across larger areas. This resulted in the inclusion of some lower-risk areas in the FTZ and, in a few cases, the exclusion of some isolated higher-risk areas from the Threat Zone. The resulting color-coded FTZ map is attached to this Fire Prevention Plan as Appendix A.

The Commission has authorized SDG&E to use its FTZ map until such time as the Commission issues its final rules and regulations governing the development and maintenance of fire-threat maps as part of Phase 3 of Rulemaking 08-11-005. SDG&E is participating in that proceeding and will update its FTZ map pursuant to the further direction of the Commission.

## 2. Mapping the HRFA

The HRFA represents those areas within the FTZ where local environmental conditions and features combine to create the highest risk of fire in the SDG&E service territory. SDG&E's Fire Coordinators, a team of in-house experts trained and experienced in fire behavior, fire prevention and firefighting, drafted the initial HRFA map in 2008. Using Geographic Information System software, SDG&E's experts identified areas where the combination of relatively dense vegetation,

relatively high winds, and development (e.g., homes, hospitals, schools, and other community assets) presented the highest risks of fire, property losses and injury from fire. Thus, the HRFA map identifies the areas marked by an overlap of (1) the "highest risk vegetation", i.e., where the vegetation was relatively dense and in close proximity to housing, business and/or community development,<sup>4</sup> and (2) locations prone to high winds.

As with the FTZ map, SDG&E utilized the FRAP data and maps available from CAL FIRE to determine the level of vegetation likely to exist in specific areas of the FTZ. Areas prone to high winds were identified using historical data from weather stations located throughout the SDG&E service territory. This included the use of data from SDG&E's private network of weather stations. The data were used to identify locations where there was a reasonable probability that wind speeds would exceed fifty miles-per-hour (50 mph) under the "Santa Ana" wind conditions usually experienced during the late summer and fall in southern California. Finally, SDG&E adjusted the HRFA map to reflect our own knowledge and information regarding conditions in our service territory.

The HRFA maps are reviewed annually and adjusted to reflect environmental conditions expected to be present during the coming year's fire season, typically the late summer and fall seasons of each year. For example, fire perimeters and other fire protection measures are updated annually and reflected in the HRFA maps. In addition, the methodologies used to develop the HRFA map are reviewed and modified to ensure that lessons learned are incorporated into the map. As an example, SDG&E assures that the HRFA includes areas where there are data indicating a coincidence of high winds and dense vegetation. As noted above, the Commission has authorized SDG&E to use its FTZ map until such time as the Commission issues its final rules and regulations governing the development and maintenance of fire-threat maps as part of Phase 3 of Rulemaking 08-11-005. SDG&E continues to participate in that proceeding and will update its HRFA map pursuant to the further direction of the Commission.

### **B. Fire-Hardening the SDG&E System**

In providing this Fire Prevention Plan, SDG&E takes note that the Commission's order focuses specifically on the measures taken by SDG&E related to the occurrence of "three-second wind gusts...that may exceed the structural or

---

<sup>4</sup> In assessing fire risks and prioritizing fire prevention activities, SDG&E considers the potential that an uncontrolled fire will threaten members of the public and/or property. Based on expert analyses provided by the Fire Coordinator team, SDG&E considers the potential path a wildfire is likely to take and prioritizes its activities along those corridors where the risk to life and property are greatest.

mechanical design standards for overhead power-line facilities." In reviewing the SDG&E Fire Prevention Plan, the Commission should be aware that SDG&E organizes its activities around addressing the threat of fire posed by various conditions and, in particular, on reducing the potential that SDG&E's facilities or operations might provide an original or contributing source of ignition for a fire. As the *Fire Safety Order* correctly anticipates, forecasted and ambient wind conditions, especially when high winds combine with the hot, dry conditions typically experienced during the late summer and fall seasons in southern California, are an important factor in assessing and addressing fire threats.

Three-second gusts represent a "measurement standard" rather than an independent "fire condition". That is, the weather instruments relied upon by SDG&E for measuring wind conditions are designed and calibrated to measure, record and report wind speeds across ten-minute periods – the average of the wind speeds recorded across any single ten-minute period is reported as the "sustained wind". In computing wind data for each ten-minute period, wind speeds are measured across three-second intervals and the highest wind speed reached during any three-second interval within any ten-minute period is separately recorded as the highest "gust" for the period. With respect to assessing and responding to the potential threat of fires, SDG&E takes potential and actual wind speeds into account, both as to sustained winds and gusts. Although both sustained wind speeds and gusts are considered, SDG&E's Fire Prevention Plan programs and activities are not designed around either wind measure. Rather, both are considered within a full range of inputs related to Fire Prevention Plan programs and activities.<sup>5</sup> The three-second interval by which "gusts" are measured is not, then, an independent operational planning standard or the focus of facility design and construction standards. Thus, SDG&E closely monitors the current weather situation and adjusts its operation to take into account current wind speeds "that may exceed the structural or mechanical design standards for overhead power-line facilities", however SDG&E's safety-related activities cannot be said to address the potential for strong wind *gusts* as a stand-alone criterion.

Using the FTZ and HRFA maps, SDG&E evaluated the prudent and cost-effective system improvements it could make to its transmission and distribution system

---

<sup>5</sup> As an example, among the non-environmental factors taken into account as SDG&E evaluates the threat of fire is whether firefighting assets are available or unavailable. Where local firefighting assets might have been previously deployed to a distant locale to fight an existing fire, SDG&E would be more conservative in assessing the actions it might take to abate or mitigate the potential threats within its service area. Winds would be a factor, but not the single determining factor under this circumstance, in deciding SDG&E's response to the local threat of fire.



which would reduce the potential for SDG&E's facilities in the FTZ and HRFA to provide the source of ignition for a fire. In part, this evaluation was performed in conjunction with the Commission's Rulemaking 08-11-005 – during Phase 1 of the proceeding, the Commission modified, with SDG&E's full support, various design, construction, maintenance, and inspection standards consistent with reducing the threat of fire posed by overhead electric and communications facilities.

#### 1. Design and Construction Standards

To reflect the more stringent design and construction standards adopted by the Commission and so as to improve the performance of the SDG&E system in terms of meeting fire-prevention goals, the SDG&E Facilities Design Manual was modified to include an entirely new section aimed at providing guidance for hardening circuits against the risk of fire. These modifications include both proactive measures designed to reduce the incidence of ignitions and reactive measures by which SDG&E can respond to the threat of fires and mitigate the spread of fires.

SDG&E is also an aggressive advocate for modernizing those portions of the Commission's General Order 95 which provide the rules and regulations governing the design and construction of overhead electric and communications facilities. SDG&E continues to participate in the discussions regarding Load and Resistance Factor Design (LRFD) and a new "High Fire Risk District" with stakeholders in Phase 3 of the Commission's Rulemaking 08-11-005, with the objective of improving General Order 95's focus on fire-safety and system-reliability objectives. Fire safety begins with the design and construction standards pursuant to which utility facilities are designed, built and operated, so improving these regulations will provide the foundation for assuring that facilities built in the future will be stronger and safer than those built under prior versions of the rules.

#### 2. Wood-to-Steel Program

Of major significance is SDG&E's program to undertake a large-scale replacement of wood poles used in those portions of the SDG&E sixty-nine (69) kilovolt transmission and twelve (12) kilovolt distribution system located in the FTZ and HRFA, substituting steel poles in their place. These poles are designed to withstand working loads under the stress of eighty-five mile-per-hour (85 mph) wind speeds. To date, SDG&E has installed over 3,900 new steel poles in the FTZ, and plans on further investment to aggressively continue to replace wood distribution and transmission poles with steel poles. These new steel pole facilities

are being installed in conjunction with the application of heavier conductors which allow SDG&E to increase the spacing between lines beyond the requirements of Commission General Order 95, resulting in a decrease in the likelihood live lines will come into contact with one another or arc after being struck by flying debris. In addition, SDG&E's current design standards now reflect the use of steel poles over wood poles in the FTZ.

### 3. Undergrounding Line Segments and Facilities

In 2011, SDG&E formed a technical team with expertise in the undergrounding of distribution systems and facilities. The team evaluated the undergrounding of various circuits, segments, elements, and equipment located in the HRFA. These experts provided senior management with an understanding of the potential for undergrounding portions of the overhead system in order to mitigate the risk of fire. The team's initial analysis identified ten (10) undergrounding projects where the potential for mitigating fire risks was promising. These projects were studied as test cases so that the team could identify and possibly resolve complexities associated with undergrounding SDG&E's facilities in the FTZ and HRFA.

Following completion of 4 these projects in 2013, undergrounding, although more costly and complex than rebuilding/hardening the overhead structures, has been determined to be a viable hardening option in the HRFA. With the CPUC's approval of Rule 20D and the criteria approved therein, SDG&E is now re-examining use of undergrounding in the HRFA required to meet the new Rule 20D guidelines. This Fire Prevention Plan will be updated later in 2014 to reflect the future scope of undergrounding upon completion of the scoping sessions.

Special Case: The Cleveland National Forest Master Special Use Permit (MSUP) and Permit to Construct (PTC) for Power Line Replacement Projects. SDG&E currently operates and maintains a network of electric facilities located within the Cleveland National Forest (CNF). In September of 2012 SDG&E filed an application for a "Master Special Use Permit" (MSUP) to operate and maintain facilities within CNF. In addition to the MSUP SDG&E worked closely with the U.S. Forest Service (USFS) to develop a series of projects and activities aimed at increasing safety and reliability of existing electric facilities within and near the CNF. Preliminary approval for these projects and associated permits have been obtained with final approval expected in May of 2015.

These projects will increase safety and reliability by replacing existing electric infrastructure that currently serves the USFS, emergency service facilities (fire,



communication and other), campgrounds, homes, businesses, and other customers within the CNF and surrounding areas. The proposed projects include replacement of several existing 12 and 69 kilovolt electric facilities spread throughout an approximately 880 square mile area in Eastern San Diego County. The existing electric lines located within CNF also extend outside of CNF boundaries. The overall project includes operational components complementing SDG&E's Community Fire Safety Program, which in turn includes community outreach, new fire prevention measures, and enhanced emergency response.

The project design was based on various recommendations addressing fire prevention and the Forest's environmental and visual values. Using an analytical matrix reflecting elements of fire risks and environmental concerns, SDG&E and the Forest Service collaborated to determine which sections of the system should be upgraded. Each segment required a custom solution based on many factors, including the location of the customer being served by the distribution system, the topography of the land, and various biological, cultural and environmental factors.

#### 4. Automated Reclosers

As part of its Community Fire Safety Program, SDG&E has undertaken one of the nation's largest deployments of state-of-the-art pulse reclosers, focusing heavily on the FTZ and HRFA. This equipment allows SDG&E to operate its system with significantly reduced energy flows during reclosing operations and be able to sectionalize various elements of its distribution system to better manage system operations and reliability. These pulse reclosers and other Supervisory Controlled and Data Acquisition ("SCADA") controlled reclosers are managed remotely by SDG&E Distribution System Operators via the SDG&E Smart Grid Network. In addition, SDG&E has implemented more sensitive relay settings to all SCADA reclosers in the HRFA. These sensitive relay settings provide very fast clearing of faults on distribution circuits and are implemented via SCADA, allowing for real-time adjustments triggered by adverse weather conditions. Importantly, these reclosers are tied to the fire-related programs described later in this Fire Prevention Plan.

#### 5. Fire Detection and Fire Alerts

In addition to improving the SDG&E system, SDG&E is leveraging its assets to address fire threats. Along these lines, SDG&E has placed high-visibility, high-resolution rotating cameras on twenty-nine (29) key towers along those portions of

the newly constructed Sunrise Power Link located in the FTZ and HRFA.<sup>6</sup> The cameras were activated in September 2012, can be controlled remotely and can rotate a full 360 degrees, and are coupled with an advanced centralized smoke-detection algorithm, which allows for early fire-detection and -warning capabilities.

SDG&E is also collaborating with the staff at the University of California, San Diego, responsible for the operation of the San Diego High-Performance Wireless Research and Education Network. This high-speed wireless data network is designed to connect hard-to-reach areas in remote environments and provide real-time data; the network includes earthquake sensors and mountaintop cameras, the latter having become a part of the emerging early fire-detection and fire-warning system being deployed in the San Diego backcountry. At this point there are a total of 19 camera locations with 4 cameras per location and two views per camera in the system, 8 of which are SDG&E installed and more are being planned. SDG&E has also engaged multiple vendors specializing in early fire detection systems, and will continue to work with these vendors to develop new and improved ways of spotting fires before they become uncontrolled wildfires.

## 6. Testing and Deploying Emerging Technologies

SDG&E is evaluating and incorporating new technologies and equipment into its overhead electric system. SDG&E's Electric Distribution Engineering Department is responsible for evaluating and creating new equipment and use standards for emerging and pre-commercial technologies. Using equipment failure data, the department determines which technologies should be incorporated into the SDG&E system and which could be improved prior to application. This department continually evaluates the many new types of technologies which may improve electric reliability and public safety, and gives special attention to technologies that may contribute to SDG&E's fire-safety goals and objectives. As an example, SDG&E is beginning to apply and analyze more advanced fault-clearing equipment that contain algorithms to improve the ability of the system to clear "wire-down" faults more quickly and which will serve to reduce the potential such faults might provide an ignition source.

---

<sup>6</sup> SDG&E plans to install another seven (7) cameras on towers located in Cleveland National Forest; installation of these cameras is pending approval by the United States Forest Service.

## 7. Facility Inspection and Repair Program

In addition to adding, redesigning and replacing facilities and elements as described above, SDG&E has implemented more stringent monitoring and inspection programs in the FTZ and HRFA, which will intensify our efforts to identify potential substandard system facilities and elements. As an example of these efforts, SDG&E is developing the use of pole-loading algorithms which more accurately calculate working loads and stresses. This area of study and change is undergoing continuous improvement to address new information, knowledge and situations. SDG&E coordinates these activities with communications infrastructure providers which jointly use SDG&E's poles and facilities.

SDG&E also maintains a comprehensive outage database which is used for reliability measurement and reporting purposes. Correlations between outages and locations are analyzed to determine whether certain equipment is prone to outage or has the potential to be an ignition source. This analysis is then matched to weather and other environmental conditions. Where it is determined that certain types of hardware have higher incidents of failure and potentially a higher incidence rate for ignition, they are replaced or prioritized for replacement. Vegetation Management also maintains a comprehensive outage database. Outages related to trees and or vegetation are investigated, documented, and results analyzed to determine if additional pruning or removal measures are warranted to prevent any reoccurrence.

SDG&E is in the process of conducting facility testing using three-dimensional light detection and ranging ("LiDAR") surveys in the HRFA. This technology is being used to perform aerial scans of the sixty-nine kilovolt transmission system in the HRFA on a three-year cycle. These surveys provide detailed depictions of terrain, vegetation and other obstacles in the vicinity of SDG&E's facilities. This data is processed and modeled by the SDG&E Power Line System Computer-Aided Design and Drafting technology to depict actual field conditions. The information produced is used to ensure safe and proper clearances are met so as to reduce the potential for line faults occurring in the HRFA. Where potential issues are discovered, SDG&E will address them by September 1<sup>st</sup>, the calendar start of the peak fire season, subject to permitting requirements and other exigencies and conditions.

## 8. Oversight of Activities in the Rural Areas

Early in 2010, a multi-disciplinary technical team of subject matter experts within SDG&E, named the "Reliability Improvements in Rural Areas Team" ("RIRAT"), was formed and tasked with (a) developing a multi-dimensional understanding of the complex fire-risk issue within the SDG&E service territory, (b) assessing the conditions which pose the greatest risks related to fire, (c) determining the level of risk mitigation that could be provided by various proposed projects, and (d) assigning priorities to capital and operating programs and projects that could address fire-related risks in the FTZ. As is evident from the FTZ map that is attached to this Fire Prevention Plan, it is in these areas where the potential for uncontrolled wildfires, and potentially the greatest losses, is the highest. The RIRAT focused its attention on facilities and activities in these areas so as to assure cost-effective fire-prevention measures are promptly evaluated and implemented.

The RIRAT was led by SDG&E'S Asset Management and Smart Grid Department and included managers and engineers from the Asset Management and Smart Grid Projects Department the Electric Transmission and Distribution Engineering Department, the Electric Regional Operations Department, and the Electric Finance and Operations Management Department.

The RIRAT, among other things, oversaw the evaluation and implementation of the various fire-hardening activities described above.<sup>7</sup> Its work was guided by the following specific goals and objectives:

- Improve the distribution system in the FTZ and HRFA;
- Develop statistical measures for assessing distribution-system performance relevant to fire-related risks so as to provide an understanding of the scope of the risks that must be addressed and develop metrics for measuring improvement;
- Identify and prioritize areas posing the greatest fire-related risks;
- Develop guidelines and a portfolio of solutions to minimize fire-related risks;
- Develop a multi-year plan for the rebuilding of circuits creating the greatest and/or most probable fire-related risks;
- Review and analyze all reports of "wire-down" occurrences; and,

---

<sup>7</sup> The Rural Area Team also oversaw the design and implementation of operations, maintenance and inspection programs and activities in the San Diego backcountry. Those activities and programs are discussed in further detail later in this Fire Prevention Plan.

- Use the "wire-down" analysis to identify causes and best solutions so as to minimize future occurrences and fire-related risks.

In order to meet their goals, the RIRAT adopted the following guiding principles:

- Utilize risk-based prioritizations to maximize risk-mitigation;
- Improve design specifications to reduce the potential for igniting fires;
- Consider and, to the extent prudent and cost-effective, employ technology-based solutions to reduce fire risks and improve overall system reliability;
- Prioritize system-rebuild efforts based on a matrix of available projects, considering the most important input factors such as the recent occurrence of a "wire-down", wind and weather conditions, fire risks, values at risk, outage history, conductor type, condition of equipment, environmental conditions, and critical customers;
- Systematically consider and evaluate the following options:
  - Fire-hardening sections of circuits or individual circuit branches;
  - Undergrounding by traditional undergrounding or cable-in-conduit;
  - Adjusting protective equipment by revising settings, balancing loads, adding reclosers, replacing expulsion fuses with fault tamers, and/or reducing fuse size; and,
  - Employing new methods and/or technologies, such as spacer cables, wireless fault indicators, "off-grid" solutions, and Smart Grid technologies;
- Replace high-risk equipment based upon statistical analytics;
- Realign circuit routings to avoid trees and dense vegetation or use tree guards and/or insulated aerial cables; and,
- Assess the costs and benefits of optional solutions for reasonableness.

The RIRAT oversaw the evaluation and approval processes for the various system improvements and capital projects described above, and specifically addressed system design and facilities from the perspective of minimizing fire-related risks in the rural areas included in the FTZ and Highest Risk Area. Recently, the RIRAT and associated processes were incorporated into a new program called the Fire Risk Mitigation (FiRM) program. This new effort is discussed in greater detail below.



## 9. Fire Risk Mitigation (FiRM) Program

In 2013, SDG&E combined the fire hardening efforts with a program designed to address pole loading issues, creating a program called the Fire Risk Mitigation (FiRM) Program. FiRM is aggressively addressing fire risk by hardening critical areas by replacing aged line elements, utilizing advanced technology, and safeguarding facilities from known local weather conditions. FiRM is being broken into multiple phases, with the scope of work varying within each phase. Also, the data analysis that has been done by RIRAT since 2010, will now be done by the FiRM Analysis Team.

In order to effectively manage the program, the overhead electric facilities in the FTZ have been segmented into smaller & more manageable groupings and prioritized based on fire risk. Statistics from the RIRAT will be coupled with information about "known local conditions" to proactively address fire risk. There is also a subset of overhead facilities (poles, wire, and equipment) that will be replaced/hardened to improve system preparedness for known local conditions. SDG&E has far more information about known local conditions than ever before, and is now using that information to upgrade areas where conditions could exceed the thresholds that were used for the original system design.

### III. Operational Practices for Reducing the Risk of Ignition

Despite all the efforts SDG&E might take in designing, redesigning, improving, replacing, and fire-hardening various elements of its overhead electric system, there will be some remaining potential risk that SDG&E's facilities might be the source of ignition for a fire. To address these risks, SDG&E has designed and implemented a number of operations, maintenance and inspection programs directly addressing fire prevention and the mitigation of effects from fires.

#### A. System Management: Quality Assurance and Quality Control

SDG&E has enhanced its system-management programs so as to assure that, to the extent possible, SDG&E's overhead system, facilities and equipment are unlikely to become the source of ignition for a fire. These programs generally encompass inspection and maintenance functions, and have been modified to focus on minimizing the probability that substandard, damaged or aging facilities will provide the ignition source for a fire. Inspection and repair of the SDG&E transmission and distribution systems have particularly intensified in the FTZ and HRFA. To that end, SDG&E performs a G.O. 165-type system maintenance

patrol of the entire overhead electric system in the FTZ on an annual basis. Safety related non-conformances identified in those patrols are scheduled for follow up repair. These patrols are twice as frequent as that required of the overhead system in general. In addition, SDG&E has implemented Quality Assurance and Quality Control standards and programs throughout its service territory, with a special focus in the HRFA during fire season.<sup>8</sup> These proactive programs are designed to identify potential structural and mechanical issues before they become actual problems. Distribution facilities within the HRFA are now inspected in detail, at minimum, on a three-year cycle, and substandard facilities (e.g., damaged equipment, missing equipment or hardware, overgrown vegetation, etc.) are noted during these inspections and trigger the issuance of a repair work-order. Where the facility in need of repair is owned by a party other than SDG&E, e.g., by a communication infrastructure provider, SDG&E will issue a notice to repair to the facility owner and work with the facility owner to ensure necessary repairs are completed promptly. SDG&E's operational goal, subject to permitting requirements and other exigencies and conditions, is to complete all facility and equipment repairs before September 1<sup>st</sup> of each year. However for 2014, because in large part of the declared drought by the Governor of California, SDG&E completed repairs one month early<sup>9</sup>

Annual adjustments to the HRFA map, if any, are also reflected in the scope of the Quality Assurance and Quality Control program.

The SDG&E Transmission Quality Assurance and Quality Control program is similar in nature to its distribution counterpart. Transmission lines within the HRFA, subject to any annual adjustments to the HRFA boundaries that might be made based on updated data, are inspected on a three-year cycle.<sup>10</sup> Matters of concern are identified for repair, and SDG&E makes best efforts, subject to permitting requirements and other exigencies and conditions, to complete all repairs within the HRFA by September 1<sup>st</sup>.

---

<sup>8</sup> The Quality Assurance and Quality Control program augments the five-year inspection cycle imposed under the provisions of Commission General Order 165.

<sup>9</sup> September 1<sup>st</sup> marks the beginning of the "fire season", although the highest risks of and from fire in the SDG&E service territory typically peak in October and November.

<sup>10</sup> The three-year inspection cycle for transmission facilities coincides with the normal cycle specified in SDG&E's Transmission Maintenance Practice manual.

## B. Enhanced Vegetation Management and Clearance Program

SDG&E currently maintains records for over 450,000 trees located near its power lines. Almost 100,000 of these trees are located within the SDG&E HRFA. All of the 450,000 trees in SDG&E's database are monitored using known species and specimen growth rates, with additional consideration given to the amount of rainfall occurring during periods affecting overall tree growth, and past pruning practices. Each tree is visited by a staff arborist on an annual cycle. The annual inspections are routine maintenance and hazard tree assessments to ensure that every tree remains fully compliant for the duration of the cycle and/or is trimmed according to accepted standards and clearances. A second inspection and corresponding tree-hazard evaluation is performed for each tree in the HRFA. To the extent unsafe clearances may exist, an order to clear vegetation is issued and trimming is completed prior to September 1<sup>st</sup> of each year. These activities ensure safe minimum vegetation clearances are achieved prior to the peak fire season.

In addition, SDG&E developed and implemented a system wide Tree Safety Program. This program assists customers in the selection of the tree species and planting locations which will minimize interference with nearby power lines and facilities. SDG&E also offers free tree replacements in the event that an existing tree cannot be maintained safely near power lines and should be removed rather than trimmed. Notably, SDG&E has, for the tenth consecutive year, been recognized by the National Arbor Day Foundation as a "Tree Line USA" utility company in recognition of our "best practices" combining worker education and training, public outreach, quality tree care, and system reliability.

SDG&E also manages over 35,000 poles within the CAL FIRE jurisdictional areas that have been designated as bearing "non-exempt" attachments.<sup>11</sup> For poles within the CAL FIRE jurisdiction that bear these "non-exempt" attachments, SDG&E is required to perform "pole brushing", that is, clearing all vegetation within a ten-foot radius of the pole. To further reduce potential ignition sources, vegetation management works closely with the RIRAT team to reduce the number of non-exempt power line components by replacing such equipment, where feasible, with exempt equipment, which should also reduce the potential for pole attachments to become an ignition source.

---

<sup>11</sup> These attachments are designated as "non-exempt" by virtue of posing some potential risk for becoming an ignition source.



### **C. Coordination with Communications Infrastructure Providers**

SDG&E has developed and rolled out a new web based communication conduit to simplify the recordkeeping for, and approval, inspection and repair of, pole attachments owned by Communications Infrastructure Providers. Named the "Telecommunication Equipment Attachment Management System" ("TEAMS"), the system was placed in operation in October 2012. TEAMS provides a direct communication link between SDG&E and Communications Infrastructure Providers and a shared-recordkeeping functionality. There are four key benefits provided by TEAMS. First, TEAMS enables Communications Infrastructure Providers to file pole attachment applications on-line – tracking of these applications and accompanying documents can now be performed electronically. This provides the baseline data necessary for SDG&E to monitor the equipment and resulting working loads placed on SDG&E facilities. Second, all attachment applications can be delivered and tracked by the applicant and SDG&E. Third, this system is also used for requesting and tracking requests for pole transfers and other transactions involving changes to equipment on jointly used poles with communications-related attachments. Finally, if during an inspection SDG&E discovers any pole attachment to be substandard and/or in need of repair, notices and the tracking of repairs will be done through TEAMS. This provides both SDG&E and the Communications Infrastructure Providers with electronic records of the actions taken by both to assure overhead facilities are in good repair and less likely to provide a source of ignition for a fire.

### **D. Workforce Training and Field Practices**

SDG&E believes that an important line of defense against the ignition of fires is a well-trained and alert workforce. Internally, SDG&E has created a culture of fire prevention. To that end, SDG&E has adopted an extensive set of work rules and complementary training programs designed to minimize the likelihood that SDG&E's facilities or field work will provide the source of ignition for a fire. The rules and training programs are in large part embodied in SDG&E Electric Standard Practice No. 113.1 ("ESP 113.1"), which specifically addresses wildland fire prevention and fire safety. ESP 113.1 was developed by SDG&E's expert team of Fire Coordinators based on their experience in fire behavior, fire prevention and firefighting techniques. ESP 113.1 also incorporates principles and concepts drawn from various federal, state and local protocols and standards addressing wildland fire prevention and suppression.

ESP 113.1 describes the conditions under which the threat of fire is considered high, and the changes in field practices and resources which will be implemented as the threat increases. These changes affect work rules, equipment which will be made available to work crews under different conditions, and even worker attire. ESP 113.1 specifies minimum training requirements and annual refresher requirements for all SDG&E and contract personnel working in the FTZ and HRFA. The work rules and training also apply to personnel working in SDG&E's Electric Distribution Operations and Electric Grid Operations centers.

As an essential part of ESP 113.1, SDG&E has adopted and implemented the principles of the Incident Command System. This system provides a structure for disciplined communications and decision-making under the threat of fire as well as during fire emergencies. SDG&E field supervisors are assigned varying levels of on-scene command responsibilities in terms of coordinating and managing the SDG&E response to threat and emergency conditions. Training in the Incident Command System protocols and responsibilities is a key element of the annual training conducted by SDG&E. ESP 113.1 is also reviewed annually and any needed changes adopted and made known to all affected.

#### **IV. Mitigating the Threat of Fire: Awareness and Readiness**

##### **A. Situational Awareness**

Although the risk of fire is a year-round reality, there are certain recurring environmental and weather conditions, particularly during the late summer and early fall, when the risks of and from fire, particularly from uncontrolled wildfires, in the SDG&E service territory are abnormally high and the dangers most severe. SDG&E's fire-prevention and risk-mitigation activities begin with intensive data gathering and data analysis so that, if and when these abnormal and dangerous conditions are anticipated or occur, SDG&E is prepared to mobilize personnel and resources to abate, mitigate and respond to these conditions and any potential fire threats.

SDG&E has developed extensive, high-resolution weather databases which are used to identify those areas where the threat of and from uncontrolled wildfire is the highest and/or most dangerous. The areas which SDG&E monitors most closely are shown in the FTZ and HRFA maps – these areas are distinguished by the coincidence of high winds and flammable vegetation. SDG&E's weather databases are constantly updated using weather data provided by a number of sources, including the United States National Weather Service, local airports, and SDG&E's proprietary network of 149 weather stations located primarily in the



FTZ.<sup>12</sup> SDG&E's private meteorological network alone provides over 200,000 data points per day.<sup>13</sup>

SDG&E has two (2) full-time degreed and experienced meteorologists on staff. Their responsibilities include analyzing the historical databases and, importantly, monitoring incoming data in real-time. They also provide a detailed daily forecast of weather conditions relevant to SDG&E's operations. Their forecasts, a combination of heat, humidity, wind, and other conditions, are combined into an "Operating Condition" assessment, which tracks the potential for fires occurring in any region of the SDG&E service territory. There are four (4) Operating Conditions used for these purposes:

- **Normal Condition:** This condition is declared across the service territory when it has been determined by the SDG&E meteorologists and Fire Coordinator team that the burn environment is not conducive for wildfires within the SDG&E service territory;
- **Elevated Condition:** This condition is declared across the service territory when it has been determined by the SDG&E meteorologists and Fire Coordinator team that the burn environment has become conducive for wildfires within the SDG&E service territory;
- **Extreme Condition:** This condition is declared for specific operating districts and regions when it has been determined by the SDG&E meteorologists and Fire Coordinator team that a combination of high winds, low relative humidity, and the burn environment will create critical fire weather conditions; and,
- **Red Flag Warning (Red Flag) Condition:** Red Flag Condition is declared by the National Weather Service when high winds and low relative humidity are forecasted to occur for an extended period of time. In elevating the Operating Condition to this level, the SDG&E staff meteorologists would be echoing the declaration.

Depending on the condition reported and broadcast by the meteorological staff, various operational changes and rules appropriate to each condition will be triggered and implemented. A table summarizing the four conditions and the associated operational responses to each is shown immediately below:

---

<sup>12</sup> The location of SDG&E's weather stations is shown on the Fire Threat Zone and Highest Risk Fire Area map attached as an appendix to this Fire Prevention Plan.

<sup>13</sup> SDG&E makes its weather data available to public agencies and the general public free of charge through several popular media outlets, including the Internet.

## Operating Chart for Normal through Red Flag Conditions

CONDITION	Normal Condition Fire Potential Index 1-11 Fuel and weather conditions are no longer conducive to significant fire growth. Based on fire indices and Fire Coordinator / Meteorologist Recommendation.		Elevated Condition Fire Potential Index 12-14 The burn environment of a specific area or district has become conducive for a large wildfire within the SDG&E service territory.		Extreme Condition Fire Potential Index 15 and above. An extreme operating condition will be declared when the burn environment of a specific area or district has become conducive for a catastrophic wildfire within the SDG&E service territory.		Red Flag Condition (NWS) (RFLW) Relative Humidity < 10%, with sustained winds > 25 mph and/or frequent gusts > 35 mph (Duration > 3 Hours) Declared by NWS.	
	Distribution	Transmission	Distribution	Transmission	Distribution	Transmission	Distribution	Transmission
Highest Risk Fire Area	No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.	
	All reclosers will be turned off.		All reclosers will be turned off.		All reclosers will be turned off. Enable Sensitive Relay Setting at direction of EDO.		All reclosers will be turned off. Enable Sensitive Relay Setting at direction of EDO.	
	TESTING		TESTING		TESTING		TESTING	
FIRE THREAT ZONE	No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.		No change to reclosing policy. Line will be tested by recloser action.	
	All reclosers will be turned off.		All reclosers will be turned off.		All reclosers will be turned off.		All reclosers will be turned off.	
	TESTING		TESTING		TESTING		TESTING	

The daily weather forecast and Operating Condition are broadcast by electronic media to personnel whose activities are affected by the declaration of the Operating Condition – the forecast, particularly when the threat of fire is high or rising, will be updated and rebroadcast as conditions warrant and as the staff meteorologists determine is appropriate. The forecast is broadcast in real-time to a large audience of SDG&E employees, including but not limited to those responsible for system operations and control, district field operations, transmission and substation operations, and communications. Senior and middle management also receive these weather updates. Personnel receiving these weather forecasts are trained to adjust their activities, duties and priorities based upon the Operating Condition reported by the staff meteorologists.

Generally, as actual or forecasted wind speeds, measured in terms of both sustained winds (the average wind speed across ten-minute intervals) and wind



gusts (the highest wind speed occurring during a three-second period within a ten-minute interval), increase, the Operating Condition will change (or "be elevated"), from "Normal" to "Elevated Condition" or "Extreme Condition" or "Red Flag Condition", depending on environmental and weather conditions and the strength of the winds being experienced or forecasted. With each step-change in the Operating Condition, personnel are placed on appropriate levels of alert. In addition, the level of system monitoring and, ultimately, system operations and activities, are elevated according to the prevailing Operating Condition. Most importantly, as wind speeds increase, SDG&E deploys an increasing number of field crews, troubleshooters and Utility Wildfire Prevention Teams to areas with the highest winds and where the greatest threat of fire exists, so as to increase the probability that fires will be detected early and a response will occur as soon as possible.

### **B. The Fire Potential Index**

SDG&E has developed a comprehensive assessment tool, known as the "Fire Potential Index" (FPI) that is used as a tool for making operational decisions which would reduce fire threats and risks. This tool converts environmental, statistical and scientific data into an easily understood forecast of the short-term fire threat which could exist for different geographical areas in the SDG&E service territory. The FPI is generated for a seven-day forecast period, and provides SDG&E personnel and threatened communities time during which they may plan and prepare accordingly.

The FPI reflects key variables such as the state of native grasses across the service territory ("green-up"), fuels (ratio of dead fuel moisture component to live fuel moisture component), and weather (sustained wind speed and dew point depression). Each of these variables is assigned a numeric value and those individual numeric values are summed to generate a Fire Potential value from zero (0) to seventeen (17), each of which expresses the degree of fire threat expected for each of the seven days included in the forecast. The numeric values are classified as "Normal", "Elevated", and "Extreme".

The state of native grasses, or "Green-Up Component", of the FPI is determined using satellite data for various locations. This component is rated on a 0-to-5 scale ranging from very wet (or "lush") to very dry (or "cured"). The scale is tied to the NDVI, which ranges from 0 to 1,<sup>14</sup> as follows:

---

<sup>14</sup> The Normalized Difference Vegetation Index ("NDVI") is a simple graphical indicator that can be used to analyze remote sensing measurements, typically but not necessarily from a space

### FPI Green-Up Component

Very Wet/Lush: 0.65 to 1.00	0.60 to 0.64	0.55 to 0.59	0.50 to 0.54	0.40 to 0.49	Very Dry/Cured 0 to 0.39
0	1	2	3	4	5

The Fuels Component of the FPI measures the overall state of potential fuels which could support a wildfire. Values are assigned based on the overall state of available fuels (dead or live) for a fire using the following equation:

$$FC = FD / LFM$$

Where FC represents "Fuels Component" in the scale below;

And FD represents Fuel Dryness Level (using a 1-to-3 scale);<sup>15</sup> and,

And LFM represents Live Fuel Moisture (percentage).

The product of this equation represents the fuels component that is reflected in the FPI as follows:

### FPI Fuels Component

Very Wet					Very Dry
1	2	3	4	5	6

platform, to assess whether the target area under observation contains live green vegetation or not. More information on the NDVI scale is available at the following address:

[http://en.wikipedia.org/wiki/Normalized\\_Difference\\_Vegetation\\_Index](http://en.wikipedia.org/wiki/Normalized_Difference_Vegetation_Index).

<sup>15</sup> These values are taken from the Southern California Geographic Area Coordination Center, an interagency support center for fire protection and suppression. More information regarding this agency can be found at the following address: <http://gacc.nifc.gov/oscc/>.

The weather component of the FPI represents a combination of sustained wind speeds and dew-point depression as determined using the following scale:

### FPI Weather Component

Dewpoint/Wind	≤4 knots	5 to 9	10 to 14	15 to 19	20 to 24	>24 knots
>50°F	2	3	3	4	5	6
40°F to 49°F	2	2	3	3	4	5
30°F to 39°F	1	2	2	3	3	4
20°F to 29°F	1	1	2	2	3	3
10°F to 19°F	0	0	1	1	1	1
<10°F	0	0	0	0	0	0

The individual numeric values representing the three variables reflected in the FPI, shown above, are combined and placed on the following scale:

### Fire Potential Index (FPI)

Normal	Elevated	Extreme
≤ 11	12 to 14	≥ 15

The FPI was developed by a team made up of SDG&E meteorologists, fire coordinator, and statistical analysts. The team has validated the FPI values and



their usefulness by recreating historical values for the past ten (10) years. The historical results bore a very strong correlation to actual fire events in terms of the severity of past fires and, in particular, provided very accurate information as to when the risks of uncontrolled and large-scale wintertime fires were high. SDG&E expects to tie proactive and reactive operational practices and measures to the FPI values, with the further expectation that SDG&E will be able to reduce the likelihood its facilities and operations will be the source of ignition for a fire during times when the risk of fire as measured by the FPI elevated or extreme.

### **C. The SDG&E Emergency Operations Center (SDG&E EOC)**

In the event the National Weather Service declares a Red Flag, the SDG&E meteorologists will elevate the warning broadcast to SDG&E personnel to the highest level of alert. Red Flags are typically issued when relative humidity is at or below fifteen percent (15%) and sustained winds are expected to reach twenty-five miles-per-hour (25 mph) or higher and/or frequent wind gusts exceeding thirty-five miles-per-hour (35 mph) are expected for a duration of six or more hours. A Red Flag will also be issued under "dry lightning conditions", where a lightning event is expected in the absence of enough precipitation to wet potential fuels which are considered critically dry. Upon the declaration of a Red Flag, SDG&E will activate the SDG&E EOC at the appropriate levels.

Because Red Flag Conditions present threats to the SDG&E electrical system and its component facilities and equipment, specific members of SDG&E management and operating departments are placed on alert when these conditions are present and the National Weather Service has issued a Red Flag. Upon such a declaration, these senior managers and operating personnel are called upon to appropriately staff the SDG&E EOC, a secure and dedicated facility which serves as a command center for SDG&E operations under high-threat conditions. The activation of the SDG&E EOC assures that appropriate decision makers and experts are assembled together, providing for the close monitoring of the electrical system and operations by all involved departments and disciplines. As the situation changes, the SDG&E EOC personnel will take appropriate and timely actions as necessary in order to protect the public safety and defend against the threat that SDG&E's electrical facilities will become a source of ignition.<sup>16</sup>

---

<sup>16</sup> Such actions may include those authorized by statute and CPUC decisions, including D.09-09-030 as modified by D.12-02-024.



#### **D. Crew Mobilization and Deployment Strategy**

During an Extreme Operating Condition or Red Flag Condition, the management of the SDG&E Electric Distribution Operations and Electric Grid Operations centers work to coordinate the assignment of appropriate and needed resources to each of the affected regional operating districts. At minimum, Electric Troubleshooters and personnel from the Utility Wildfire Prevention Team are made available for immediate response to address fire threats or events. If the event is more severe, additional resources will be coordinated between and assigned from Electric Distribution Operations, Electric Grid Operations, Electric Regional Operations, Construction Services, and Kearny Substation and Transmission Operations Center to manage the event. Field personnel may be assigned to observe an area forecasted to experience the most adverse weather conditions – these personnel are under instructions to report flying debris, vegetation damage, or significant conductor movement. Based on these field observations, SDG&E deploys appropriate resources to address the fire threats posed by these conditions.

#### **E. Field Patrols**

Under Elevated, Extreme and Red Flag Conditions, SDG&E may perform an appropriate patrol of any circuit within the SDG&E Threat Zone suffering a forced outage. Qualified electrical workers are dispatched to inspect the circuit, determine the cause of the outage, and evaluate the physical integrity of the circuit. Upon the appropriate evaluation, restoration will commence when repairs are completed and/or there is no longer a threat to public safety or the electric system. In some cases, and weather permitting, field personnel may be positioned to observe and test the affected circuit.

Training and refresher drills for field patrols are conducted annually and are designed to exercise the assembly of Patrol Teams and the communication hierarchy of the SDG&E Incident Command System. These drills ensure effective management of the Restoration Patrols and disciplined communications between Patrol Teams, Patrol Leaders, Fire Coordinators, and Incident Commanders.

#### **V. Fire Suppression and Recovery**

When fire risk is high and a wildland fire occurs, SDG&E will mobilize its available resources (Utility Wildfire Prevention Team and Industrial Fire Brigade, see below) to assist in coordinating the suppression of the fire and in post-event recovery

activities. In many instances, these resources are also made available to the public agencies with responsibility for fire suppression and recovery.

#### **A. Fire Coordination Personnel**

SDG&E employs a full-time staff of Fire Coordinators and contracts for additional resources and personnel on an as-needed, project-by-project basis. The four Fire Coordinators currently on staff have over a century of firefighting experience and are experts in fire behavior, fire prevention and firefighting techniques. The Fire Coordinators serve as the direct link between SDG&E and emergency-response agencies. They also serve as the single point of contact for the fire agency Incident Command System, provide periodic updates to fire emergency personnel and SDG&E personnel, establish radio and communications assignments for every fire event, assist in the coordination of activities related to de-energizing and re-energizing power lines, and update on-scene personnel, control centers, service dispatch, and the SDG&E operations centers as to the status of each incident. The Fire Coordinators are active in professional forums, seminars and training throughout the service territory to ensure state-of-the-art fire practices are incorporated into SDG&E operations and practices. The Fire Coordinators also participate in engineering and operational meetings to advise SDG&E personnel regarding fire threats and prevention.

The Fire Coordinators also share information with the firefighting agencies within the SDG&E service territory and, on a rotating basis, provide those agencies with electrical and gas safety training.

#### **B. Firefighting Assets and Resources**

##### **1. Utility Wildfire Prevention Team**

SDG&E has contracted for wildland fire-suppression trucks and trained firefighting personnel. Up to eight (8) fire suppression trucks are provided to SDG&E throughout the fire season, and are available to SDG&E on an on-call basis for the other months of the year. These resources are dispatched with work crews during days on which the threat of fire is high. Prior to the commencement of the day's work, firefighting personnel provide instruction and advice specifically addressing fire risks and the potential mitigation and prevention measures the crews should observe in order to eliminate or reduce the likelihood of an ignition. The firefighting crews also pre-deploy hose lines and tools as a precautionary measure and monitor the work performed by the SDG&E crews.



In the event of an ignition, the firefighting personnel have the equipment, skills and ability to respond and extinguish fires quickly.

When the fire risk is very high, SDG&E deploys additional fire trucks as needed pursuant to a proactive staging plan triggered by the declaration of "Extreme Conditions" and "Red Flag Conditions". These resources are strategically placed throughout the service territory to be available as needed.

## 2. Aviation Services Department

This department is responsible for contracting aviation assets and personnel, planning, supporting and managing day-to-day aviation activities, measuring aerial job performance, and supporting fire-suppression activities. With respect to its fire-suppression responsibilities, the department coordinates the provision of SDG&E aerial resources to firefighting efforts. The department also oversees SDG&E's contributions to, and participation in, the local Aerial Firefighting Protection Fund in collaboration with the San Diego Fire Department and the San Diego County Office of Emergency Services.

SDG&E has also contracted with Erickson Air-Crane for the provision of a Type 1 firefighting helicopter from September 1<sup>st</sup> through November 30<sup>th</sup> through the year 2016. This contract is under the supervision of the Department.

## 3. The Industrial Fire Brigade

SDG&E has contracted a full-time Industrial Fire Brigade. The Brigade is on duty and available to SDG&E on an around-the-clock basis. The Brigade is made up of a Brigade Leader and three (3) shifts consisting of a Fire Captain, Fire Engineer, and two (2) firefighters. The Brigade is specially trained in fighting fires involving electrical equipment and flammable liquids. The Brigade members are housed in facilities located near the geographical center of the SDG&E service territory and are fully equipped to handle utility-related fire emergencies.

The Brigade has available four (4) portable trailers, each provisioned with 300 gallons of Class B Alcohol Resistant firefighting foam, 500 pounds of PKP Dry Chemical extinguishing agent, a 500 gallon-per-minute monitor, and two self-educating handlines designed to work with hydrants or other mobile fire apparatus. The newest of these trailers are located in Boulder City, Nevada, near the SDG&E

Desert Star Power Plant, and at an Imperial County Fire Station, close to the SDG&E Imperial Valley Substation.

The Brigade is also responsible for the development of comprehensive pre-emergency response plans for each SDG&E facility. These plans will be developed for SDG&E's high-value assets first, including SDG&E's power plants, peaker stations, and extra-high-voltage substations. These plans are designed to improve emergency response at each of these facilities significantly.

#### 4. Miscellaneous Assets

SDG&E maintains a collection of portable emergency generators which may be deployed on an as-available basis to customer locations to provide temporary power during electrical outages. These generators will generally be made available to providers of essential services as a first priority but could be made available, if available, to other customers upon request and on a case-by-case basis.

SDG&E has been proactive in developing programs and partnerships which significantly improve emergency-event communications both internally and in cooperation with emergency-services agencies. In this regard, SDG&E has acquired Mobile Field Command Trailers and satellite phone booths for forward deployment and to assure uninterrupted essential communications during emergencies. SDG&E has also been integral in the creation of an Area Situational Awareness for Public Safety Network (or "ASAPnet"), which has been designed and deployed to provide internet connectivity to and between more than seventy (70) fire stations throughout the San Diego County backcountry.

#### C. Recovery Activities

At the end of emergency events, the SDG&E Emergency Operations Center conducts regular tabletop and functional training exercises and debriefs on potential issues ranging from cybersecurity to catastrophic fires. Debriefs are conducted following each exercise and activation of the Emergency Operations Center.

Also, SDG&E employees participate in a number of volunteer and charitable activities on an ongoing basis – this participation expands dramatically following local disasters. These activities include providing human, financial and other resources to the American Red Cross, San Diego County Recovery, the San Diego Burn Institute, and many other worthy organizations.

#### D. Fire Incident Data Collection Plan

Contained within Phase 3, Track 2 of the on-going Fire Safety OIR proceedings the parties jointly developed a plan for the IOU's to collect and report data to SED regarding power line fires, and for SED to use this data to (1) identify and assess systemic fire safety risks associated with overhead power line facilities and (2) formulate measures to reduce the number of fires ignited by power lines. SDG&E has adopted the plan developed by the parties within the proceeding and further has created a plan specific to SDG&E's initiation and implementation of these requirements to insure compliance.

The CPUC/SED requirements can be summarized by the following bullets:

- Any data collection and subsequent data reporting will be in addition to the incident reporting requirements currently required of the utilities.
- Data needs to be consistent using the default formats provided within the proceeding.
- New fire reporting requirements should not be limited to designated "fire threat" zones or districts but for all areas.
- Fire reporting shall meet the following criteria;
  - Self-propagating fire of material other than electrical and/or communication facilities.
  - The resulting fire traveled greater than (1) meter from the ignition point.
  - The utility has knowledge the fire occurred.
- Information shall be objective and factual.
- Utilities will report data in an annual report for the previous calendar year before April 1<sup>st</sup> of each year.
- The data collected is raw data that is correct to the best of the utility's knowledge at the time of submission.

The SDG&E Data Collection plan further specifies responsibilities and accountability for compliance with this plan;

- Fire Coordination: The Fire Coordination group will continue to manage the current fire database and continue to work with Emergency Services to move this process into the SDG&E Emergency Incident Reporting (EIR) system. The transition will occur without disruption or loss of data as well as be able to generate the required report. All qualifying fires will be reported to the On-duty Fire Coordinator.
- Compliance Management: As part of their annual calendar, Compliance Management will track and insure that this reporting requirement to the SED is met in the required timeframe.
- Claims, Legal, & Regulatory: Will continue their role and responsibilities for fires related to SDG&E facilities as well as review the annual report prior to submission.



- Control Centers: Both Distribution Operations and Grid Operations supervisors and operators will understand what denotes a reportable fire and assist in insuring qualifying fires are reported to the On-duty Fire Coordinator.
- Electric Regional Operations and Transmission Construction Maintenance: Troubleshooters, Construction Supervisors, and line personnel will understand what denotes a reportable fire and assist in insuring qualifying fires are reported to the On-duty Fire Coordinator.
- Training: An initial training and annual refresher training will be developed by the Fire Coordination group and delivered to the Control Center and District field personnel to insure compliance with these requirements.
- Root Cause Analysis: The data collected will continue to be shared internally with the T&D engineering group for further root cause analysis to help determine fire mitigation measures that make sense to implement in the future.

## **VI. Community Outreach and Public Awareness**

SDG&E has created a multi-level approach to community education and outreach as our contribution to public awareness of fire threats, fire prevention and emergency preparedness. The key elements of this approach are described below.

### **A. Fire Safety Stakeholder Council**

SDG&E frequently invites community leaders and the public at-large to participate in a collaborative fire-safety process. About forty (40) stakeholders, including representatives of local school districts, water districts, disability rights advocates, consumer groups, and fire agencies, have been working with SDG&E to develop a joint fire-prevention and emergency-action plan. This collaboration has produced more than 100 potential solutions aimed at preventing the occurrence of major fires. SDG&E is implementing many of the solutions identified by these stakeholders, including deactivating automated reclosers, hardening its overhead electrical system through the use of steel poles and larger conductors, and undergrounding portions of the backcountry electrical system, where feasible.

### **B. Partnering with Firefighting Agencies**

SDG&E partners with the San Diego County Fire Chiefs' Association and fifty-three (53) other organizations to address a range of fire prevention and

emergency activities. These partners include; fire agencies, Fire-Safe councils, Community Emergency Response Teams (CERTs) and other community organizations. Among the activities addressed through these partnerships are, including but not limited to:

- Participation in coordinated multi-agency preparedness and emergency events;
- Support of the annual May County Wildland Drill;
- Participation in Fire Station Open Houses and Fire Safe Councils, prior to and through the fire season;
- Emergency preparedness radio spots with the San Diego County Fire Chiefs' Association and the American Red Cross; The provision and underwriting of grants by SDG&E to support Volunteer Fire Fighters, CAL FIRE Public Information Officer Command Vehicles, Burn Institute programs, and the San Diego Kids Fire Safety Program;
- Fire-safety media campaigns in conjunction with the American Red Cross and local television station KUSI-TV; and,
- The "Prepare San Diego Partnership" and Sheltering Memorandum-of-Understanding executed by and with the American Red Cross.

SDG&E also chairs the California Utilities Emergency Association, a collaboration between utilities, emergency services agencies and the California Emergency Management Agency.

### **C. Community Partnerships**

SDG&E is proud to support non-profit organizations whose programs promote emergency preparedness and safety at home and in our communities. In 2012, SDG&E began providing funds to charitable organizations committed to regional and local emergency preparedness and fire safety, such as 2-1-1 San Diego, the American Red Cross, and the Burn Institute, plus dozens of volunteer fire departments, Community Emergency Response Teams, and Fire Safe Councils.

SDG&E provides regular communications to residents and businesses located in the FTZ and HRFA. These fire-safety and emergency communications include, but are not limited to;

- Customer education events, emergency preparedness symposiums for businesses, public participation meetings, and backup generator safety workshops;
- Informational and emergency preparedness mailings to customers in the HRFA;
- Educational advertising campaigns focusing on SDG&E's preparations for the fire season and the preparations SDG&E's customers should make for emergencies;
- Educational information disseminated through the Energy Notes newsletter distributed with customer billings;
- Distribution of a co-branded "newsletter" with the American Red Cross, the San Diego Office of Emergency Services, and the County Fire Chiefs Association;
- Distribution of the "Z-Card", which provides formatted emergency information that easily folds and fits in an automobile glove box or emergency kit;
- Distribution of "refrigerator magnets" bearing important emergency information;
- The provision of weather information and system-outage status on SDGE.com;
- Dissemination of information regarding emergency-preparedness events via social media, such as Twitter and Facebook;
- Opt-in campaign offering customers electronic-mail access to safety checklists and fire-safety videos;
- Publication of information for SAFE San Diego Education and Outreach events in the community following an emergency.

In addition to routine outreach and communications, SDG&E intensifies its effort to communicate with customers when fire-threat conditions are elevated or extreme. SDG&E has instituted an early warning system advising customers that a Red Flag has been declared by the National Weather Service and dangerously high winds are expected. SDG&E also opens communications with local water districts, telecommunications infrastructure providers, the San Diego County Office of Education, the San Diego County Office of Emergency Services, and the American Red Cross as soon as possible following the declaration of a Red Flag. SDG&E assembles a team, including members from Commercial and Industrial Services, SDG&E's Meteorological Department, and SDG&E's Electric Distributions Operations center, to provide updates on the status of the SDG&E system and weather conditions.



As alert conditions are elevated, SDG&E also contacts, directly and indirectly, disabled customers and Medical Baseline (MBL) customers. Under severe threats of emergencies, where SDG&E cannot make contact with these customers via our outbound-dialer system, SDG&E will send field personnel to make personal contact and, failing all else, to leave door hangers alerting the customer of the situation.

#### **D. Fire Preparedness Website**

SDG&E maintains a publicly accessible website focused on safety, including gas safety, electric safety, fire safety, tree safety, emergency preparedness, generator safety, and outage information. SDG&E Emergency Preparedness Brochures, Z-Cards, radio spots, print advertisements, and social media postings via Facebook and Twitter, have been utilized to distribute and provide links to SDG&E's emergency preparedness and safety website:

<http://www.sdge.com/safety/fire-safety/proactive-approach-fire-prevention>

Additional fire-related websites supported and maintained by SDG&E are accessible using the following addresses:

- Emergency Preparedness web pages: <http://www.sdge.com/safety>
- Weather and Outage web pages: <http://www.sdge.com/tools/windspeed-dashboard>

#### **E. Fire Mitigation Funds**

In addition to providing various fire-prevention and -preparedness grants as described above, SDG&E funds two fire-mitigation programs as a part of the Sunrise Power Link Project. These programs, known as the "Powerline Firefighting Mitigation Fund" and the "Defensible Space and Structure Hardening Grants Fund", are operated subject to agreements with various firefighting agencies whose jurisdictions include lands along the Sunrise Power Link transmission corridor.

The Powerline Firefighting Mitigation Fund was used to provide a lump sum to each of the seven fire agencies with jurisdiction along the transmission line route. Each agency received \$556,524, for a total disbursement of \$3.9 million – these funds were used to purchase new fire trucks and communications equipment, increase fire patrols, and fund additional personnel during the fire season. The agencies receiving these funds include CAL FIRE, Federal Bureau of Land Management, County of San Diego, City of San Diego Fire & Rescue Department,

Alpine Fire Protection District, Lakeside Fire Protection District, and the San Diego Rural Fire Protection District.

The Defensible Space & Structure Hardening Grants Program was implemented in 2012 and will remain in place as long as the Sunrise Power Link is in service. A grants contractor, Environmental Resource Solutions (ERS), has been hired and is implementing a Public Education and Outreach Program for eligible property owners, developing the grant application website and other program requirements. The program provides funding for the creation and maintenance of defensible space around homes in close proximity to the Sunrise Power Link. This defensible space will bring those homes into with compliance with various fire codes so as to assist firefighters in minimizing structure and property damage. These funds may also be used to fire-harden structures by retrofitting rooftops with fire-resistant materials, installing fire shutters and double-pane windows, cave boxing, and removing and/or replacing wood fencing and/or decks. SDG&E annually provides \$2.8 million (2008\$) to fund the program.

Appendix A

2014 Map of SDG&E FTZ,  
And Meteorological Network

