

**ORA DATA REQUEST
ORA-SDGE-170-TCR
SDG&E 2019 GRC – A.17-10-007
SDG&E RESPONSE
DATE RECEIVED: MARCH 22, 2018
DATE RESPONDED: MARCH 30, 2018**

Exhibit Reference: SDG&E-14

SDG&E Witness: Alan F. Colton

Subject: Substation not shown on RAM map

Please provide the following:

1. During ORA's site visits on March 20, 2018, ORA saw what appeared to be a relatively new low profile substation at the corner of Mira Sorrento Place and Vista Sorrento parkway, as indicated by the red boxes in the images below (street view appears to show a substation.) The RAM map does not indicate a substation at this location. If there is a substation at this location please provide:

- a. The name of the substation, voltage levels, and operational date,
- b. Budget code used to design and build the substation,
- c. List all transmission and distribution circuits connected to this substation,
- d. If this substation is not included in DRP DR-5, attached, please provide all information requested in DRP DR-5 Question 1 for this substation.

SDG&E Response 01:

SDG&E objects to this request to the extent it requests information that is not within the scope of the TY 2019 GRC. Subject to and without waiving this objection, SDG&E states as follows:

- a. Mira Sorrento Substation, 69kV/12kV, Operational in 2014
- b. Budget 2252 in SDG&E's TY 2016 General Rate Case
- c. The transmission and distribution circuits connected to this substation consist of two 69kV circuits and seven 12kV circuits.
- d. Yes, it is included.